



- NOTES**
- DO NOT SCALE FROM THIS DRAWING.
 - THIS DRAWING REPRESENTS THE DESIGN GENERALITY IN ACCORDANCE WITH STAGE 2 FOR DESIGN & BUILD AND AS SUCH REPRESENTS DESIGN DEVELOPMENT AT THIS STAGE AND DOES NOT CONTAIN ALL THE INFORMATION REQUIRED TO FORM A BILL AND TO BE WORKING INSTALLATION WITHOUT FURTHER DESIGN DEVELOPMENT FROM THE CONTRACTOR.
 - READ IN CONJUNCTION WITH THE RELEVANT SECTION OF THE SPECIFICATION.

- KEY**
- SMOKE EXTRACT GRILL
 - SMOKE FRESH AIR SUPPLY GRILL
 - AUTOMATIC SMOKE DAMPER LINKED TO NEW F&R ALARM
 - AUTOMATICALLY OPENING VENT, MIN FREE AREA 0.4 M²
 - DRY RISER INLET BREACHING VALVE
 - DRY RISER LANDING VALVE
 - RISEING MAN
 - ISOLATION VALVE
 - P.F.C. - LOW LEVEL CONDENSED
 - P.F.C. - LOW / F.V.F. EXPOSED
 - P.F.C. - HIGH LEVEL - EXPOSED
 - P.F.C. - HIGH LEVEL - CONDENSED

11/11/13	STAGE 2 TENDER ISSUE	xyz
rev	date	description

MAX FORDHAM

Max Fordham LLP
42-43 Cloister Crescent
London
EC4A 3DF
maxfordham.com

Registered in England No. 03200044
Registered Office 15-17 Cloister Court London EC4A 3DF

architect
STUDIO E ARCHITECTS
Job title
REFURBISHMENT
project leader date score (out of 10)
DC NOV 2013 1:50
Drawing title
GROUND FLOOR COMBINED SERVICES MECHANICAL
Job no dwg no rev
J4614 T(90)12_001/T1