

Butler & Young Lift Consultants Ltd



LIFT CONSULTANCY SERVICES

Timber Hall
21 Timber Lane
Caterham
Surrey CR3 6LZ
Tel: [REDACTED]
Fax: [REDACTED]
Email: liftconserv@btinternet.com

Also:
c/o Corporation of London
Milton Court, Moor Lane
Barbican, London
EC2Y 8DR
Tel/Fax: [REDACTED]

Our Ref: L2508/SBE/CW

21st December 2004

Mr G Poynter
Apex Lift & Escalator Engineers Ltd
Apex House
LEFA Business Park
Edgington Park
Sidcup
Kent
DA14 5BH

Dear Mr Poynter,

Re: Grenfell Tower

Please find enclosed the following drawing with our comments:

C5469/008

We have no further comments in GA's 5469/001 Rev B sheets 1, 2 and 3 - HO90/91.

Our only comments on drawing No C5471/001 - HO92:

- i. Should show multi stage hydraulic - not roped.
- ii. Incorporate steady guide.
- iii. Incorporate m/r features as Hann Tucker report.
- iv. Paint bund yellow / black stripes.
- v. Any special measures for reduced overtravel - notified body etc.

Trust this will be in order. Please ensure revised drawings received in this office no later than the 14th January 2005.

Yours sincerely

Steve Ellis

Enclosure