

Message

From: Woodham, Bill [/O=SGMAIL/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=WOODHAM, BILL7CF]
Sent: 24/03/2015 08:16:48
To: Berger, Debbie [dberger@celotex.co.uk]
CC: Seaton, Lizzie [eseaton@celotex.co.uk]; Roome, Jonathan [jroome@celotex.co.uk]; Evans, Paul [pevans@celotex.co.uk]
Subject: RE: RS5000 Test Data inconsistencies

Hi all,

My personal view is this is an issue. Our route to market is using competitive advantage technically which means we refer end users to technical data and system approvals,

If we send them away they will be looking at system build ups and I think our two documents need to reflect one another.

For example the value matrix exercise we covered at launch we identified K15 and the fact that only 80mm K15 was tested.

So if our literature is correct then the wording on the BS8414-2 test report needs to be revised or vice versa.

Please keep me in the loop regarding the outcome.

Regards

Bill Woodham

Regional Sales Manager - North

BWoodham@celotex.co.uk

Twitter: @BWoodhamCelotex

Mob: [REDACTED]



Celotex
SAINT-GOBAIN

Celotex.
Reaching new heights



Celotex Limited, Lady Lane Industrial Estate, Hadleigh, Ipswich, Suffolk, IP7 6BA
Celotex Limited is registered in England with Company number 2183896.
Registered Office: Saint-Gobain House, Binley Business Park, Coventry, CV3 2TT.

celotex.co.uk
 @Celotex



Please consider the environment before printing this email

From: Berger, Debbie
Sent: 23 March 2015 13:13
To: Roome, Jonathan; Evans, Paul
Cc: Woodham, Bill; Seaton, Lizzie
Subject: RE: RS5000 Test Data inconsistencies

Hi Jonathan

This must be an oversight. Thanks for letting us know.

I'll let Lizzie know so that it can be corrected next print run.

Were there any other queries regarding this inconsistency? Although it's not technically mirroring the system tested, it's unlikely the small difference in plasterboard thickness will influence RS5000 compliance.

If it causes an issue then let me know and I will seek advice.

Kind regards

Debbie Berger

Product Manager

dberger@celotex.co.uk

Ext:

Mob:



Celotex
SAINT-GOBAIN

Celotex.
Reaching new heights



Celotex Limited, Lady Lane Industrial Estate, Hadleigh, Ipswich, Suffolk, IP7 6BA
Celotex Limited is registered in England with Company number 2183896.
Registered Office: Saint-Gobain House, Binley Business Park, Coventry, CV3 2TT.

celotex.co.uk
[@Celotex](https://twitter.com/Celotex)



Please consider the environment before printing this email

From: Roome, Jonathan

Sent: 23 March 2015 13:07

To: Evans, Paul; Berger, Debbie

Cc: Woodham, Bill

Subject: RS5000 Test Data inconsistencies

Morning Paul,

It has been brought to my attention that in our Spec Guide for RS5000 the tested system shows 2 x 12.5mm plasterboard but the BS8414:2 test shows 2 x 10mm plasterboard.

Has this been highlighted before?

Kind regards,

Jonathan

Jonathan Roome

Major Projects and Specification Manager

jroome@celotex.co.uk

Twitter: @JonathanCelotex

Mob:

DDI:

Tel:

Fax: [REDACTED]

Web: celotex.co.uk

Follow: [@Celotex](https://twitter.com/Celotex)



Celotex
SAINT-GOBAIN

Celotex. Reaching new heights



Celotex Limited, Lady Lane Industrial Estate, Hadleigh, Ipswich, Suffolk, IP7 6BA
Celotex Limited is registered in England with Company number 2183896.
Registered Office: Saint-Gobain House, Binley Business Park, Coventry, CV3 2TT.

celotex.co.uk

@Celotex



Please consider the environment before printing this email

Celotex Limited, registered in England, Company Number 02183896. Registered Office Saint Gobain House, Binley Business Park, Coventry, CV3 2TT

The information transmitted including any attachments is intended only for the exclusive use of the person(s) or entity to which it is addressed and may contain confidential and privileged material that may be subject to legal privilege. Any perusal, review, retransmission, dissemination, distribution, reproduction or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient without the sender's prior consent is unauthorised and strictly prohibited. If you have received this message in error, please notify the sender immediately and delete the message from your computer without making any copies. Any personal views and opinions expressed in this e-mail message are the sender's own and do not necessarily represent the views and opinions of the Company.