

Message

From: [REDACTED]
Sent: 25/11/2016 11:48:10
To: jwray@kctmo.org.uk
Subject: Re: Grenfell Tower - Gas Reinstatement

Morning Janice

The issue of open ended boxing is interesting.

Please let me know the answer.

From a fire safety prospectus as the pipe pass through any compartment floor, wall or ceiling it must be fire stopped to the fire rating of that compartment lining so the wall onto the staircase is 60 minutes. If it is to be installed within a riser, which one? The drawings do not make this clear, where is the boxing being fitted? ie surface mounted in the lift lobby areas?

What materials will the boxing be constructed of.

A lot more information is needed on this subject.

This is a Building Control issue, what are their thoughts?

A Building Control final certificate will be needed on completion along with Gas safe certificates etc

Carl

-----Original Message-----

From: Janice Wray <jwray@kctmo.org.uk>
To: Carl Stokes [REDACTED]
Sent: Thu, 24 Nov 2016 20:38
Subject: Fwd: Grenfell Tower - Gas Reinstatement

C

Could you please take a look at this and let me have any comments or requirements

Thanks

J

Sent from Samsung Mobile

----- Original message -----

From: Charlie Saul <csaul@kctmo.org.uk>
Date: 24/11/2016 15:10 (GMT+00:00)
To: Janice Wray <jwray@kctmo.org.uk>
Subject: Grenfell Tower - Gas Reinstatement

Hi Janice,

As I'm sure you may have heard, the gas supply to Grenfell Tower has been capped to one of the risers by National Grid due to a gas leak.

Attached are their proposed plans to re-instate the gas to the block.

CST00003111_0001

CST00003111/1

We have queried the affects the 'open ended boxing' may have compartmentation of the stairwell/lobby areas and are awaiting response.

Are there any further question that health and safety or Carl would like answered about the proposal before permission is granted to progress the works?

Kind regards,

Charlie

Charlie Saul
Contracts Manager
Assets and Regeneration
Kensington & Chelsea TMO

csaul@kctmo.org.uk

[kctmo logo email]
www.kctmo.org.uk<<http://www.kctmo.org.uk/>>

292a Kensal Road, London, W10 5BE
P Before printing, please think about the environment

This e-mail message has been scanned for Viruses and Content and cleared
by MailMarshal
#####

.
.
.
DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.

This e-mail and all attachments is CONFIDENTIAL.
If received in error please delete it. The TMO monitors and records all e-mail that it sends and receives.
Unless stated explicitly, this message does NOT form a legally binding contract or agreement.
