
From: Paul Dunkerton <pdunkerton@kctmo.org.uk>
Sent: 11 September 2012 11:03
To: 'Bruce Sounes'; Grenfell; Terry Ashton
Subject: FW: Grenfell Tower Regeneration - Fire Strategy
Attachments: Fire at Grenfell Tower - Friday 30th April 2010 - e-mail to LFB.htm

Bruce / Terry

Please find response from our Health & Safety officer below and attached email.

Regards
Paul D

From: Janice Wray
Sent: 11 September 2012 10:54
To: Paul Dunkerton
Cc: Ricki Sams; Adrian Bowman
Subject: RE: Grenfell Tower Regeneration - Fire Strategy

Hi Paul

As per conversation just now I have attached an e-mail I sent to the LFB's Fire Safety Officer following a fire in the common parts of Grenfell Tower in April 2010. Unfortunately, as I have outlined the vents did not operate as required during this fire which led to pressure on us from the LFB. Subsequent to this correspondence Keith Fifield, our then Building Services Manager, and I met with the LFB at Grenfell Tower. However, as commonly happens none of this was put in writing by the LFB. I believe that this and further investigations undertaken by RGE, our Planned Maintenance contractor, led to Keith & his team concluding that this system needed to be replaced / refurbished. I'm afraid I was not involved in the detail of progressing this or drafting the specification.

Hope this helps

Janice

Janice Wray
TMO Health, Safety & Facilities Manager
t: [REDACTED]



w: www.kctmo.org.uk
a: : The Network Hub, 300 Kensal Road, W10 5BE

 Before printing, please think about the environment

From: Paul Dunkerton
Sent: 11 September 2012 10:45

To: Janice Wray; Adrian Bowman
Cc: Grenfell; Terry Ashton; 'Bruce Sounes'; Ricki Sams
Subject: RE: Grenfell Tower Regeneration - Fire Strategy

Bruce,

By way of this email I pass your request for information onto Janice Wray and Adrian Bowman, our Health & Safety officers, who will be able to assist.

Janice
Please read email below.

Thank you.

Regards
Paul D

From: Bruce Sounes [<mailto:bruce@studioe.co.uk>]
Sent: 10 September 2012 17:03
To: Paul Dunkerton
Cc: Ricki Sams; Grenfell; Terry Ashton
Subject: Grenfell Tower Regeneration - Fire Strategy

Hi Paul,

You forwarded us a specification for the upgrade to the alarm and smoke extract in July. It was prepared by Aecom and dated October 2011.

Presumably this was the result of feedback from the London Fire Brigade? Our fire consultant (Exova) would like to know if there was anything received in writing outlining their concerns with the current system. If not, how was the specification arrived at? I think it was Ricky Sams who originally raised this back in May so I have included him on the email.

Many thanks.

Bruce Sounes

For and on behalf of
STUDIO E LLP

Palace Wharf, Rainville Road, London W6 9HN
T [REDACTED] | F [REDACTED] | www.studioe.co.uk



Queen's Award for Enterprise: Sustainable Development 2010
BCSE Award School Architect of the Year 2008 & 2010
BCSE Award Inspiring Design Primary School 2008 & Academy 2010
BSF Award Excellence in Student Engagement 2009
Sustainable City Award 2009



Please consider the environment before printing this email.

ELECTRONIC INFORMATION TRANSFER DISCLAIMER

This email and any files transmitted with it are sent for and on behalf of Studio E and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender. All attached files are copyright and may only be used for the purpose stated in the drawing status box. In the event that the files are altered in anyway, it is a condition of use that the Studio E name and logo be removed from the modified file, unless prior written agreement has been obtained. Studio E will assume no responsibility for the accuracy, adequacy, and integrity of the files, and recommends that the files be thoroughly screened for viruses prior to installation. Opinions, conclusions and other information expressed in this message are not given or endorsed by Studio E LLP unless otherwise indicated by an authorised representative independent of this message.

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.