

Message

From: M.Smith@maxfordham.com [M.Smith@maxfordham.com]
Sent: 06/01/2015 15:09:33
To: Terry Ashton [Terry.Ashton@Exova.com]
CC: d.campbell@maxfordham.com; philip.booth@uk.arteliagroup.com
Subject: Grenfell Tower - Smoke Extract System
Attachments: 011 AOV.docx; Apollo Smoke Heads.pdf; Grenfell Tower Tech Sub Lobby Smoke Control Systems Rev 1.pdf; KEY-1.pdf; osr_brochure.pdf; Pressure Transmitter 1240_415_REV_F.pdf; sc_series[1].pdf; SERIES_54.pdf; smokevent_slcs.pdf

Afternoon Terry

Can you look over and provide comment on the smoke extract proposal put forward by PSB on behalf of JS Wright? It looks acceptable and I believe the principle of it has been verbally accepted by Building Control, but it may be wise to get your view as it falls slightly outside our area of expertise.

It's fundamentally different to what we specified in that it is now a pressure differential system rather than simple smoke clearance. Details can be found below. If you have any questions then please give me a call.

Kind regards,

Matt

MAX FORDHAM

42-43 Gloucester Crescent

London

NW1 7PE

T

F

maxfordham.com

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales Number OC300026
Registered office 42-43 Gloucester Crescent, London, NW1 7PE

EXO00000344_0001

EXO00000344/1