



Request for Information Form

To:	Simon Lawrence	From:	Daniel Anketell-Jones	
Company:	Rydons	Company:	Harley	
Project Name:	Grenfell Tower	Date/Time:	17 th September 2014	
Job No:	C1059	Rydon Query No:	Harley Query No:	
			001	
Date Answer is Required:	26 th September 2014	Date Answer was Received:		
Query:				
Please may you confirm the required extent of the horizontal firebreaks within the cladding areas?				
Suggested Solution:				
We believe that they will be required at every floor level on the vertical columns, but not in the area of cladding between windows. This is because there is no 'chimney' effect here, and therefore the cladding will not add to the spread of fire.				
Distribution for Response				
Answer:		Copy to	Company	
		Signature	Date:	