From: Neil Crawford <Neil@studioe.co.uk>

 Sent:
 06 March 2015 15:50

 To:
 Paul.Hanson@rbkc.gov.uk

Cc: john.hoban@rbkc.gov.uk; slawrence@rydon.co.uk; Kevin Lamb; Simon O'Connor

(SOConnor@rydon.co.uk); Jason North (jnorth@rydon.co.uk)

Subject: FW: Grenfell

Attachments: 855 C1059 GA Model 33 202C (1).pdf; 855 C1059 GA Model 33 201D (1).pdf; 855 C1059 GA

Model 33 200I (1).pdf; 855 C1059 GA Model 33 100A (1).pdf; 855 C1059 Grenfell Tower Register

Sht 1.pdf; 855 C1059 GA Model 33 305C (1).pdf; 855 C1059 GA Model 33 301E (1).pdf

Hi Paul

Following our conversation this afternoon, this reminded me of another issue. Where we are over cladding what fire rating do we need to allow for within the wall build up between apartments (see below and attached)?

Regards

Neil

From: Kevin Lamb [mailto:KevinLamb@harleycw.co.uk]

Sent: 03 March 2015 12:58 **To:** slawrence@rydon.co.uk

Cc: Neil Crawford; Bruce Sounes; Daniel Anketell-Jones; Mark Stapley; Rob Maxwel; Ben Bailey

Subject: Grenfell

Simon,

Please find attached drawings now showing the fire breaks, both horizontal and vertical.

We assume a requirement of 90min integrity & 30min insulation is sufficient, if not please advise.

The vertical breaks are not on all columns, just party walls.

Regards

Kevin Lamb Project Designer



T-F-

W- www.harleycurtainwall.com

Head Office

Harley House, Brooklands Park Farningham Road, Crowborough East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.