



CERTIFICATE FOR IDENTIFICATION OF ASBESTOS FIBRES

STANDARD ☐
PREMIUM ☐
EMERGENCY ☐

Client:	EXPRESS ENVIRONMENTAL SOLUTIONS LTD
Address:	2 ESSEX ENTERPRISE CENTRE 33 NOBEL SQUARE BASILDON ESSEX SS13 1LT
Attention:	T. PEARCE
Site Address:	31 GRENFELL TOWER LONDON
Date sample taken:	UNKNOWN
Date sample received:	24/10/16
Date of Analysis:	24/10/16

Analysis Report No.	SCO/16/24152
Report Date:	24/10/16
Site Ref No.	N/A
Page No:	1 Of 1
No. of Samples:	2
Obtained:	DELIVERED

Samples of material, referenced below, have been examined to determine the presence of asbestos fibres, using Scopes Asbestos Analysis "in house" method of transmitted/polarised light microscopy and centre stop dispersion staining, based on HSE's HSG248.
If samples have been DELIVERED the site address and actual sample location is as given by the client at the time of delivery. Scopes Asbestos Analysis Services Limited are not responsible for the accuracy or competence of the sampling by third parties. Under these circumstances Scopes Asbestos Analysis Services Limited cannot be held responsible for the interpretation of the results shown.

SCOPES SAMPLE No.	CLIENT SAMPLE No.	Sample Location	Fibre Type Detected
1	AC002524	BEDROOM- CEILING COATING	CHRYSTOTILE
2	AC002525	CUPBOARD 1- INFILL PANEL	AMOSITE/CHRYSTOTILE

KEY: NADIS - No Asbestos Detected in Sample

Note: All samples will be retained for a minimum of six months.

Note: This Certificate for Identification of Asbestos Fibres shall not be reproduced except in full without the written approval of the Laboratory.

Analysed by:	P ROWLAND	Authorised signatory:	
		Print name:	S BOLTON- Q.C.M

BULK 001-VER 5 12-AUGUST-09-QCM

2 Nobel Square, Courtauld Road, Burnt Mills Industrial Estate, Basildon, Essex SS13 1LS

E-Mail: enquiries@scopesaasl.co.uk

Company Reg No: 5191390 Reg Address: As above

