

# MEMORANDUM

---

To: John Hoban  
cc:

From: Paul Hanson  
Dated: 24/6/2015

---

## B1 - MEANS OF ESCAPE OBSERVATIONS

**PREMISES:** Grenfell Tower, Grenfell Road

**APP No:** Submission 1a

**SUBMISSION No:** S1a

**DOCUMENTS:** J S Wright & Co Limited

Smoke Ventilation Technical submission PSBUK1143-12 rev 3 12<sup>th</sup> June 2015

I make the following comments using **Approved Document B** and, where appropriate, **BS 9991**.

**Comments to client**

**Powered ventilation system serving single stairway lobbies**

The proposals outlined in the Smoke Ventilation Technical submission PSBUK1143-12 rev 3 are satisfactory.

1. I note that there is the intention to bring the ventilation system down to also serve the existing ground level lobby adjacent to the lifts and switch room.
2. Final details of the key switch arrangements should be submitted when finalised.
3. Generally the components of the system should conform to the **Guidance on Smoke Control to Common Escape Routes in Apartment Buildings (Flats and Maisonettes) Revision 1: June 2012** listed in section 11.3.