

## Alan Whyte

---

**From:** Paul.Hanson@rbkc.gov.uk  
**Sent:** 24 June 2015 15:22  
**To:** David Bradbury  
**Cc:** hm@psbuk.com; John.Hoban@rbkc.gov.uk; Neil@studioe.co.uk  
**Subject:** RE: Grenfell Tower AOV technical Submission  
**Attachments:** MOE Obs Grenfell Tower, Grenfell Road S1a smoke control system.docx

Hi Dave,

Please find attached my comments regarding the smoke control system for the stairway lobbies; the proposals for which are satisfactory.

Regards.

Paul Hanson  
Senior Building Control Surveyor (Fire Regulations)  
Royal Borough of Kensington and Chelsea  
T. [REDACTED]  
M. [REDACTED]  
F. [REDACTED]  
W. [www.rbkc.gov.uk/buildingcontrol](http://www.rbkc.gov.uk/buildingcontrol)

View the latest video covering the [Holland Park School Redevelopment](#)

Building Control media and publications are available by clicking on the following link:- [Publications](#)

---

**From:** David Bradbury [mailto:DavidBradbury@jswright.co.uk]  
**Sent:** 14 April 2015 16:56  
**To:** Hanson, Paul: PC-Plan  
**Cc:** Hoban, John: PC-Plan; Hugh Mahoney; Simon Lawrence  
**Subject:** Grenfell Tower AOV technical Submission

Hi Paul,

Following our meeting regarding the AOV system at Grenfell Tower, please find attached a copy of the amended technical submission for your approval.

Please note: the key switch has not been changed due to awaiting a client decision, the key switch will therefore be subject to final confirmation, we can amend the tech sub accordingly and keep track of the changes if it does change. Hope this is acceptable.

Any questions please do not hesitate to contact me.

Kind regards,

Dave Bradbury  
Design Manager  
Head Office

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: [davidbradbury@jswright.co.uk](mailto:davidbradbury@jswright.co.uk) | Web: [www.jswright.co.uk](http://www.jswright.co.uk)

**J S WRIGHT & CO LTD, CELEBRATING 125 YEARS, 1890 – 2015**

HOTEL	LEISURE	COMMERCIAL	INDUSTRIAL	RESIDENTIAL	CARE HOMES
-------	---------	------------	------------	-------------	------------

# MEMORANDUM

---

To: John Hoban  
cc:

From: Paul Hanson  
Dated: 24/6/2015

---

## B1 - MEANS OF ESCAPE OBSERVATIONS

PREMISES: Grenfell Tower, Grenfell Road  
APP No: Submission 1a  
SUBMISSION No: S1a  
DOCUMENTS: JS Wright & Co Limited  
Smoke Ventilation Technical submission PSBUK1143-12 rev 3 12<sup>th</sup> June 2015

I make the following comments using Approved Document B and, where appropriate, BS 9991.

### **Comments to client**

**Powered ventilation system serving single stairway lobbies**

The proposals outlined in the Smoke Ventilation Technical submission PSBUK1143-12 rev 3 are satisfactory.

1. i note that there is the intention to bring the ventilation system down to also serves the existing ground level lobby adjacent to the lifts and switch room.
2. Final details of the key switch arrangements should be submitted when finalised.
3. Generally the components of the system should conform to the Guidance on Smoke Control to Common Escape Routes in Apartment Buildings (Flats and Maisonettes) Revision 1: June 2012 listed in section 11.3.