

THE GRENFELL TOWER INQUIRY

EXHIBIT DPB/20

This is the Exhibit marked “DPB/20”
referred to in the witness statement
of David Paul Bradbury

Phil Leech

From: Paul.Hanson@rbkc.gov.uk
Sent: 24 June 2015 15:22
To: David Bradbury
Cc: hm@psbuk.com; John.Hoban@rbkc.gov.uk; Neil@studioe.co.uk
Subject: RE: Grenfell Tower AOV technical Submission
Attachments: MOE Obs Grenfell Tower, Grenfell Road S1a smoke control system.docx

Hi Dave,

Please find attached my comments regarding the smoke control system for the stairway lobbies; the proposals for which are satisfactory.

Regards.

Paul Hanson
Senior Building Control Surveyor (Fire Regulations)
Royal Borough of Kensington and Chelsea

..

M.

F.

W. www.rbkc.gov.uk/buildingcontrol

View the latest video covering the [Holland Park School Redevelopment](#)

Building Control media and publications are available by clicking on the following link:- [Publications](#)

From: David Bradbury [mailto:DavidBradbury@jswright.co.uk]
Sent: 14 April 2015 16:56
To: Hanson, Paul: PC-Plan
Cc: Hoban, John: PC-Plan; Hugh Mahoney; Simon Lawrence
Subject: Grenfell Tower AOV technical Submission

Hi Paul,

Following our meeting regarding the AOV system at Grenfell Tower, please find attached a copy of the amended technical submission for your approval.

Please note: the key switch has not been changed due to awaiting a client decision, the key switch will therefore be subject to final confirmation, we can amend the tech sub accordingly and keep track of the changes if it does change. Hope this is acceptable.

Any questions please do not hesitate to contact me.

Kind regards,

Dave Bradbury
Design Manager
Head Office

Tel: 020 822 1000 | Fax: [REDACTED] | Mob: [REDACTED] | Email: davidbradbury@jswright.co.uk | Web: www.jswright.co.uk

J S WRIGHT & CO LTD, CELEBRATING 125 YEARS, 1890 – 2015

One of the Leading Mechanical & Plumbing Design & Installation Companies in the UK

Head Office - J S Wright & Co Ltd, The Atlas Building, 16 Portland Street, Aston, Birmingham, B6 5RX
London Office - J S Wright & Co Ltd, 1 Northumberland Avenue, London, WC2N 5BW Tel: [REDACTED]
Bristol Office - J S Wright & Co. Ltd, Trym Lodge, 1 Henbury Road, Westbury-on-Trym, Bristol, BS9 3HQ Tel: 0 [REDACTED]

The contents of this email and any attachments are the property of J S Wright & Co Limited and are for the confidential use of the named recipient(s) only. They may be legally privileged and should not be communicated to or relied upon by any person without our express written consent. If you are not an addressee please notify us immediately at <mailto:jswright@jswright.co.uk>. Any files attached to this email will have been checked with virus detection software before transmission. However, you should carry out your own virus check before opening any attachment. J S Wright & Co Limited accepts no liability for any loss or damage which may be caused by software viruses.



Please Consider the Environment before Printing this E-mail

InTRANSIT Festival of Arts Friday 19 to Sunday 28 June. Lots of free events to enjoy.
Check it out <http://www.rbkc.gov.uk/intransit>

Ask Nick: Conversation and question time with Council Leader, Cllr Nick Paget-Brown.
Thursday 9 July, 6pm to 8pm, Holy Trinity Brompton, SW7 1JA.

Submit your question and register to attend at <http://www.rbkc.gov.uk/asknick>

The Royal Borough of Kensington and Chelsea.

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.

This e-mail has been scanned for all viruses by Claranet. The service is powered by MessageLabs. For more information on a proactive anti-virus service working around the clock, around the globe, visit:
<http://www.claranet.co.uk>

MEMORANDUM

To: John Hoban
cc:

From: Paul Hanson
Dated: 24/6/2015

B1 - MEANS OF ESCAPE OBSERVATIONS

PREMISES: Grenfell Tower, Grenfell Road

APP No: Submission 1a

SUBMISSION No: S1a

DOCUMENTS: J S Wright & Co Limited

Smoke Ventilation Technical submission PSBUK1143-12 rev 3 12th June 2015

I make the following comments using Approved Document B and, where appropriate, BS 9991.

Comments to client

Powered ventilation system serving single stairway lobbies

The proposals outlined in the Smoke Ventilation Technical submission PSBUK1143-12 rev 3 are satisfactory.

1. I note that there is the intention to bring the ventilation system down to also serves the existing ground level lobby adjacent to the lifts and switch room.
2. Final details of the key switch arrangements should be submitted when finalised.
3. Generally the components of the system should conform to the Guidance on Smoke Control to Common Escape Routes in Apartment Buildings (Flats and Maisonettes) Revision 1: June 2012 listed in section 11.3.