

THE GRENFELL TOWER INQUIRY

EXHIBIT ZC/8

This is the Exhibit marked “ZC/8”
referred to in the witness statement
of Shkelzen Canaj



GRENFELL TOWER - SMOKE EXTRACT SYSTEM

BASIC HOW TO USE GUIDE WHEN ACTIVATED

CHECKING STATUS OF SMOKE DAMPERS

1. At Main Menu - press the 'STATUS SCREEN' button
2. Select the 'SMOKE DAMPER' option
3. See table on opposite page for location of each damper

OVERVIEW FOR MANUAL CONTROL OF INDIVIDUAL FLOORS

1. Switch key on main panel from 'AUTO' to 'ON' setting
2. 2nd Key can be used in yellow 'SMOKE EXTRACT' key switch in each lift lobby to manually operate dampers on individual floors

NOTE: Only one floor can be manually controlled at a time

RESETTING FIRE PANEL

1. At Main Menu - press the 'RESET FIRE SIGNAL' button

IN CASE OF FALSE ALARM

1. At Main Menu - press the 'RESET FIRE SIGNAL' button

DAMPER ID	LOCATION
AUTO 1	Ground Floor - Community Room Lobby
AUTO 2	2nd Floor - Bowling Club Lobby
SD 01	1st Floor - Lift Lobby
SD 02	1st Floor - Lift Lobby
SD 03	1st Floor - Lift Lobby
SD 04	1st Floor - Lift Lobby
SD 05	1st Floor - Lift Lobby
SD 06	1st Floor - Lift Lobby
SD 07	1st Floor - Lift Lobby
SD 08	1st Floor - Lift Lobby
SD 09	1st Floor - Lift Lobby
SD 10	1st Floor - Lift Lobby
SD 11	1st Floor - Lift Lobby
SD 12	1st Floor - Lift Lobby
SD 13	1st Floor - Lift Lobby
SD 14	1st Floor - Lift Lobby
SD 15	1st Floor - Lift Lobby
SD 16	1st Floor - Lift Lobby
SD 17	1st Floor - Lift Lobby
SD 18	1st Floor - Lift Lobby
SD 19	1st Floor - Lift Lobby
SD 20	1st Floor - Lift Lobby
SD 21	1st Floor - Lift Lobby
SD 22	1st Floor - Lift Lobby
SD 23	1st Floor - Lift Lobby
SD 24	1st Floor - Lift Lobby
SD 25	1st Floor - Lift Lobby
SD 26	1st Floor - Lift Lobby
SD 27	1st Floor - Lift Lobby
SD 28	1st Floor - Lift Lobby
SD 29	1st Floor - Lift Lobby
SD 30	1st Floor - Lift Lobby
SD 31	1st Floor - Lift Lobby
SD 32	1st Floor - Lift Lobby
SD 33	1st Floor - Lift Lobby
SD 34	1st Floor - Lift Lobby
SD 35	1st Floor - Lift Lobby
SD 36	1st Floor - Lift Lobby
SD 37	1st Floor - Lift Lobby
SD 38	1st Floor - Lift Lobby
SD 39	1st Floor - Lift Lobby
SD 40	1st Floor - Lift Lobby
SD 41	1st Floor - Lift Lobby
SD 42	1st Floor - Lift Lobby
SD 43	1st Floor - Lift Lobby
SD 44	1st Floor - Lift Lobby
SD 45	1st Floor - Lift Lobby
SD 46	1st Floor - Lift Lobby
SD 47	1st Floor - Lift Lobby