


# THE GRENFELL TOWER INQUIRY

---

## EXHIBIT TNG/8

---

This is the Exhibit marked “TNG/8”  
referred to in the witness statement  
of Tobias Neville Guise

Grenfell Tower 9497						GREEN HIGHLIGHT - VERY GOOD STANDARD	YELLOW HIGHLIGHT - NOT YET ACTIONED						CALL OUT RISK			POTENTIAL COST OF CALL			DATE RECTIFIED
No of Inspections	Item Number	DATE OF INSPECTION	BLOCK / FLOOR / PLOT	LOCATION	ISSUE DESCRIPTION / STANDARD	PICTURE	JSW / SUB CONTRACTOR	Underlining issue	SNAGGED Y / N	COMMISSIONED	HANDED OVER	GOOD PRACTICE	LOW	MEDIUM	HIGH	LOW	MEDIUM	HIGH	
10	1	08/12/2015	Flat 4	Kitchen	Flex ductwork under the sink requires a new length of flex as it has been squashed		JSW	Ductwork	N	N	N				1		1		