

---

**From:** Paul.Hanson@rbkc.gov.uk  
**Sent:** 03 September 2014 08:40  
**To:** David Bradbury  
**Cc:** Robin Thorne; Alan Whyte; slawrence@rydon.co.uk; SOConnor@rydon.co.uk; Neil@studioe.co.uk; bruce@studioe.co.uk; Terence McLaughlin; 'John.hoban@rbkc.gov.uk'  
**Subject:** RE: Grenfell Tower  
**Attachments:** image001.jpg

Hi David,

Thank you for your email and I note:-

. We are not increasing the high of the existing riser but we are adding two additional floors at low level which were previously walkways. We understand the existing riser is above the current permitted height of 50 meters, we would therefore need to discuss the proposed modification and what measures we need to take to gain approval for the new system.

This sounds like a matter of control rather than a technical question, I have spoken to John Hoban the area surveyor, who would normally deal with matters on control, and he agreed in this instance with my sending you this response.

Essentially the building regulations cannot require you to improve the system to serve the existing floors over 50m.

The regulations only apply to the work being carried out and additionally you must not adversely affect the existing building.

If this does not answer the question please give me a ring to discuss further.

Regards.

Paul Hanson  
Senior Building Control Surveyor (Fire Regulations)  
Royal Borough of Kensington and Chelsea  
T.   
M.   
F.   
W. [www.rbkc.gov.uk/buildingcontrol](http://www.rbkc.gov.uk/buildingcontrol)

View the latest video covering the [Holland Park School Redevelopment](#)

Building Control media and publications are available by clicking on the following link:- [Publications](#)

---

**From:** David Bradbury [mailto:DavidBradbury@jswright.co.uk]  
**Sent:** 03 September 2014 08:06  
**To:** Hanson, Paul: PC-BlgCtrl; 'John.hoban@rbkc.gov.uk'  
**Cc:** Robin Thorne; Alan Whyte; Simon Lawrence; Simon O'Connor; Neil@studioe.co.uk; Bruce Sounes; Terence McLaughlin  
**Subject:** FW: Grenfell Tower

Morning Paul,

I sent a message to John Hoban yesterday regarding the dry riser at Grenfell Tower, however I've been informed you may be the person to speak to regarding fire issues?

Kind regards,

Dave Bradbury  
Senior Design Engineer

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: [davidbradbury@jswright.co.uk](mailto:davidbradbury@jswright.co.uk) | Web: [www.jswright.co.uk](http://www.jswright.co.uk)

---

**From:** David Bradbury  
**Sent:** 02 September 2014 15:59  
**To:** 'John.hoban@rbkc.gov.uk'  
**Cc:** Terence McLaughlin; Robin Thorne; Alan Whyte; 'Simon Lawrence'; Simon O'Connor; 'Neil@studioe.co.uk'; 'Bruce Sounes'  
**Subject:** Grenfell Tower

Hi John,

Simon Lawrence from Rydon has passed on your details, I'd like to introduce myself as I am currently working on the refurbishment of the above mentioned project. We will be carrying out the mechanical and electrical works associated with the refurbishment.


One of the items I need to discuss with you is the modifications to the existing dry riser. We are not increasing the high of the existing riser but we are adding two additional floors at low level which were previously walkways. We understand the existing riser is above the current permitted height of 50 meters, we would therefore need to discuss the proposed modification and what measures we need to take to gain approval for the new system.

I have tried to call but I understand you are currently out of the office, please call me when you can on the number below, alternatively I will try calling again tomorrow morning. Thank you.

Kind regards,

Dave Bradbury  
Senior Design Engineer

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: [davidbradbury@jswright.co.uk](mailto:davidbradbury@jswright.co.uk) | Web: [www.jswright.co.uk](http://www.jswright.co.uk)

 The linked image cannot be displayed. The file may have been moved, renamed, or deleted. Verify that the link points to the correct file and location.

---

**One of the Leading Mechanical & Plumbing Design & Installation Companies in the UK**  
**Winners of the H&V Award for "Outstanding Contribution to the Industry 2013"**

Head Office - J S Wright & Co Ltd, The Atlas Building, 16 Portland Street, Aston, Birmingham, B6 5RX  
London Office - J S Wright & Co Ltd, 1 Northumberland Avenue, London, WC2N 5BW Tel: [REDACTED]

The contents of this email and any attachments are the property of J S Wright & Co Limited and are for the confidential use of the named recipient(s) only. They may be legally privileged and should not be communicated to or relied upon by any person without our express written consent. If you are not an addressee please notify us immediately at [mailto:jswright@jswright.co.uk](mailto:mailto:jswright@jswright.co.uk). Any files attached to this email will have been checked with virus detection software before transmission. However, you should carry out your own virus check before opening any attachment. J S Wright & Co Limited accepts no liability for any loss or damage which may be caused by software viruses.



**Please Consider the Environment before Printing this E-mail**

Hundreds of free or low cost activities and events this summer for the family and young people.

Download Summer in the City <http://www.rbkc.gov.uk/summerinthecity>

Check out our Ecology events in Holland Park <http://www.rbkc.gov.uk/ecology>

\*\*\*\*\*

The Royal Borough of Kensington and Chelsea.

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.

\*\*\*\*\*

---

This e-mail has been scanned for all viruses by Claranet. The service is powered by MessageLabs. For more information on a proactive anti-virus service working around the clock, around the globe, visit: <http://www.claranet.co.uk>

---