

Appendix F: Witness Statement of Adrian Pargeter: Kooltherm FM Pipe Insulation Product Tests

	Title of Test	Date of Report	Test House	Product	Report Number	Classification	Relativity/Exhibit Number
1	EN 13501-1:2007+A1: 2009	22 January 2014	Exova Warringtonfire	Kooltherm Pipe Insulation	336867	Fire behaviour: BL Smoke production: s1 Flaming droplets: d0	AP/44/[]
2	EN 13501-1:2007+A1: 2009	21 March 2016	Exova Warringtonfire	Kooltherm Pipe Insulation	361596	Fire behaviour: BL Smoke production: s1 Flaming droplets: d0	AP/45/[]

	Title of Test	Date of Report	Test House	Product	Report Number	Classification	Relativity/Exhibit Number
3	EN 13501-1:2007+A1: 2009	5 December 2016	Exova Warringtonfire	Kooltherm Pipe Insulation	370711	Fire behaviour: BL Smoke production: s1 Flaming droplets: d0	AP/46/[]