



AlliedProtection

Part of the Lakehouse Group

INSPECTION & SERVICING CERTIFICATE (Automated Opening Vents)

Tel: 0845 223 2223,
Fax: 0845 226 2225
service@alliedprotection.co.uk

Client Name: Lakehouse - K&T - Kensington & Chelsea TMO
Property Address: Grenfell Tower 11-206, Lancaster West Estate, , W11 1TQ
Job Number: K&C195982-1
Date: 17.01.17

Description of works carried out:
Service of the aovs

Tests / Checks done

YES / NO / N/A

Actuators working Correctly?

Yes

Clean, Lubricate and tighten all actuators, dampers and
louvres?

Yes

Left Vents in Closed Position?

Yes

Control and Indicating Equipment operating correctly?

Yes

Power Supply test OK?

Yes

Back up Batteries test OK?

Yes

Wiring OK?

Yes

Rain / Wind Sensors tested?

N/A

Interfacing confirmed as working?

N/A

Smoke detectors tested?

N/A


Cause and Effects Tested?

Yes

Cause & Effects arrangements & Checks completed:
Service of the aovs

Comments / Remedial Works required:

Service of the aovs

Customer Signature: 

Client/Representative's Name: A

Engineer Signature: 

Arrival Time: 09.00

Engineer Name: Karl Russell

Departure Time: 12.00



Head Office : Unit 2, Regent Business Centre, Jubilee Rd, Burgess Hill, W Sussex, RH15 9TL

LAK00000009/1
LAK00000009/1