

Message

From: MCHUGH, MICHELE [MICHELE.MCHUGH@london-fire.gov.uk]
Sent: 12/12/2016 13:00:45
To: 'Janice Wray' [jwray@kctmo.org.uk]
Subject: RE: Barandon Walk Deficiency Notice

Hi Janice,

I'm so sorry for the delay in getting back to you but we've been really busy carrying out audits.

Regarding this block – we normally only sample a couple of doors any way but in this instance my findings were based on the wording of your Fire Risk Assessor who stated “These flat entrance doors were at one time open to atmosphere so the doors and windows are not fire rated if they are the originally fitted ones.”

The on-site representative also stated that many of the doors were not fire doors.

Kind Regards

Michele McHugh
Fire Safety Inspecting Officer

Fire Safety Regulation
London Fire Brigade Headquarters
T [REDACTED]
Mob [REDACTED]
E michele.mchugh@london-fire.gov.uk

From: Janice Wray [mailto:jwray@kctmo.org.uk]
Sent: 25 November 2016 16:33
To: MCHUGH, MICHELE
Cc: BURTON, REBECCA; Barbara Matthews
Subject: Barandon Walk Deficiency Notice
Importance: High

Hi Michele

I have just receive your Deficiency Notice for this block but it would be helpful if you could please be more specific about the Issue you have raised. I would assume that you recorded the doors that you believe to be non-compliant - could I please have this information as this will enable me to swiftly interrogate our records and check, in the first instance, whether the doors in question have been assessed and if not for me to arrange for them to be assessed and upgraded / replaced as required.

Please advise

Regards

Janice

Janice Wray
TMO Health, Safety & Facilities Manager
t: [REDACTED]



w: www.kctmo.org.uk
a: 292a Kensal Road, London, W10 5BE.

Before printing, please think about the environment

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.