

Incoming Email
from

Dil Singh
<Dil@rgeservices.co.uk>

on
23/01/2014 13:48

Create Mail Reply

File Ref 1 Mechanical Contractor

File Ref 2 None

File Ref 3 None

To: "M.Smith@maxfordham.com" <M.Smith@maxfordham.com>; Simon Coleman
<Simon@rgeservices.co.uk>

cc: "d.campbell@maxfordham.com" <d.campbell@maxfordham.com>

Subject: RE: Grenfell - smoke extract system

Associated Documents

created by: Dil Singh on 23-Jan-14

J:\4614\INCOMING\20140123_001 RGE Smoke Venting Report\Extractir Fans Maintainance
Report - Grenfell Tower.pdf

Hi Matt,

We trust all is well.

Please find attached report of vent system and our recommendations.

We have stated every service to the TMO that in the event of a activation, we cannot guarantee that the system will work.

Should you require any further assistance, please do not hesitate in contacting us.

Many thanks,

Regards,

Dil Singh

rgeservices ltd

Office:

Mobile:

Email: dil@rgeservices.co.uk

Please consider your environmental responsibilities before printing this email.

This electronic message contains information from RGE Services Ltd which may be privileged or confidential. The information is intended to be for the use of the individual's or entity named above. If you are not the intended recipient, be aware that any disclosure, copying distribution or use of the contents of this information is prohibited. If you have received this electronic message in error, please notify us by telephone or email (to the numbers or address above) immediately.

From: M.Smith@maxfordham.com [mailto:M.Smith@maxfordham.com]

Sent: 23 January 2014 11:45

To: Simon Coleman

Cc: Dil Singh; d.campbell@maxfordham.com

Subject: Re: Grenfell - smoke extract system

Simon - Thanks. That would be great. If it arrives before 1pm that would be ideal...

Cheers,

Matt

MAX FORDHAM

42-43 Gloucester Crescent

London

NW1 7PE

T

F

maxfordham.com

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales
Number OC300026
Registered office 42-43 Gloucester Crescent, London, NW1 7PE

From: Simon Coleman <Simon@rgeservices.co.uk>
To: "M.Smith@maxfordham.com" <M.Smith@maxfordham.com>,
Cc: "d.campbell@maxfordham.com" <d.campbell@maxfordham.com>, Dil Singh <Dil@rgeservices.co.uk>
Date: 23/01/2014 11:41
Subject: Re: Grenfell - smoke extract system

Hi Matt,

I have been out on site this morning.
I will see what we have, and forward to you asap today.

Simon coleman

Sent from Samsung Mobile

----- Original message -----

From: M.Smith@maxfordham.com
Date: 23/01/2014 10:11 (GMT+00:00)
To: Simon Coleman
Cc: d.campbell@maxfordham.com
Subject: Grenfell - smoke extract system

Morning Simon

Thanks for talking me through the smoke extract system yesterday. As I mentioned at the time, it would be great if you could forward me any paperwork you have for it; maintenance records, test reports etc.

We also need to have the performance measured to satisfy Building Control about our designs for the new extract. Could you provide me with a day rate and an hourly rate for the attendance of someone from RGE who is familiar with the system to aid a testing company to measure the flow rates etc? It will most likely be to open/close dampers and so on. I'll try and get this arranged in the next week or two.

Kind regards,

Matt

MAX FORDHAM

42-43 Gloucester Crescent

London

NW1 7PE

T

F

maxfordham.com

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales

Number OC300026

Registered office 42-43 Gloucester Crescent, London, NW1 7PE