

**Outgoing  
Email**

from

Matt Smith

on

23/10/2014 11:07

Create Mail Reply

File Ref 1 Main Contractor

File Ref 2 None

File Ref 3 None

To: "Simon Lawrence" <slawrence@rydon.co.uk>

cc: philip.booth@uk.arteliagroup.com; "Claire Williams" <clwilliams@kctmo.org.uk>;  
CN=Duncan Campbell/O=MaxFordham@MaxFordham

Subject: Grenfell - Fire alarm auto-dialler

Associated Documents

created by: **Matt Smith** on 23-Oct-14

Morning Simon

Following your query on the provision of a phone line for the fire panel at Grenfell I've been through the ERs and found that we have included for a dial-up connection for remote monitoring. The extract from p41 is below:

Central Panel:

As described in Section U10 above, a central control panel shall be provided for the lift lobbies smoke control system. In addition to the indication provided for the smoke system, provide indication of fire being detected in any of the new areas described above. The Contractor shall include for the cost of this panel, but shall discuss with Building Control to agree if this is required or not.

Include for a dial-up connection to the local Fire Brigade or an approved monitoring centre.

Kind regards,

Matt

**MAX FORDHAM**

42-43 Gloucester Crescent

London

NW1 7PE

T

F

[maxfordham.com](http://maxfordham.com)

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales Number OC300026

**MAX00004519/1**  
MAX00004519/1

Registered office 42-43 Gloucester Crescent, London, NW1 7PE