

**Outgoing
Email**

from

Matt Smith

on

06/01/2015 15:09

Create Mail Reply

File Ref 1 Fire Engineering

File Ref 2 None

File Ref 3 None

To: "Terry Ashton" [REDACTED]

cc: CN=Duncan Campbell/[REDACTED]
[REDACTED]

Subject: Grenfell Tower - Smoke Extract System

Associated Documents

created by: **Matt Smith** on 06-Jan-15

9 attachments



011 AOV.docx



Apollo Smoke Heads.pdf



Grenfell Tower Tech Sub Lobby Smoke Control Systems Rev 1.pdf



osr_brochure.pdf



Pressure Transmitter 1240_415_REV_F.pdf



KEY-1.pdf



sc_series[1].pdf



SERIES_54.pdf



smokevent_slcs.pdf

Afternoon Terry

Can you look over and provide comment on the smoke extract proposal put forward by PSB on behalf of JS Wright? It looks acceptable and I believe the principle of it has been verbally accepted by Building Control, but it may be wise to get your view as it falls slightly outside our area of expertise.

It's fundamentally different to what we specified in that it is now a pressure differential system rather than simple smoke clearance. Details can be found below. If you have any questions then please give me a call.

Kind regards,

Matt

MAX FORDHAM

42-43 Gloucester Crescent

London

NW1 7PE

T: [REDACTED]

F: [REDACTED]

maxfordham.com

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales Number OC300026
Registered office 42-43 Gloucester Crescent, London, NW1 7PE