

05/07/13

TIAN WILLS

APPARANT LEAK FROM COMUNAL PIPE
PIPE LAGGING WET. LEAK HAS STOPPED
NOW. BUT IS AN ONGOING PROBLEM

ALL FLATS ABOVE NEED TO BE SURVEYED
COMUNAL HOT WATER TANK NEEDS
TO BE CHECKED, MAYBE AN EXPANSION
OVERFLOW AS WATER STARTED TO BUILD UP
AGAIN - URGENT ATTENTION NEEDED

CONRAD HAS ALREADY VISITED ON 30/6/13
FOR SAME PROBLEM, BUT IT HASNT BEEN SOLVED
AS YET

FROM - TMO CONTRACTOR.

WILLMOTT DIXON DATED
5TH JULY 2013 AT 8pm.

2