

Job Number	PD807175	Customer Order Number	
Unit Number	PD807175	Parts Used	
Site Address	Grenfell Tower Grenfell Road London W11 1TG		
Unit Reference	H091		
Date of Service Visit Report	19/12/2016		
Visit Type	M2		

Works Completed

As part of the scheduled maintenance visit, the below items were checked by our engineer and found to be serviceable :

Car Enclosure and COP
Emergency Alarm System
Indicators and Call Buttons
Floor Levels and Selector
Machine and Brake
Operation of Car Doors
Car Top
Shaft Equipment

Observations

full shaft cleandown, deep clean in motor room and on car top strongly required when builders have finished works. door operator needs setting up once builders have finished works. hanger rollers in car at ground and 2nd specifically need to be changed car hanger rollers changed fan wiring should be separate from car lighting pit ladders required for both lifts and barriers lg1 nov visit

Total Time on Site 2.00

Total Travel to Site 0.00

Customer Name	Customer Unavailable For Signature
Signed Date & Time	

Signature Declined	N
Decline Reason	

Attending Engineer(s)						
Engineer Name	Date Attended	Site Arrival	Site Depart	Time on site	Travel to site	Customer Signoffs
D Smalley (55029)	16/12/16	15:00	17:00	2.00	0.00	N/A