

IN A MATTER CONCERNING THE GRENFELL TOWER INQUIRY

EXHIBIT MW/2



Job Number	PD807175	Customer Order Number								
Unit Number	PD807175	Parts Used								
Site Address	Grenfell Tower Grenfell Road London W11 1TG									
Unit Reference	H091									
Date of Service Visit Report	27/04/2017									
Visit Type	M2									
Works Completed		Observations								
<p>As part of the scheduled maintenance visit, the below items were checked by our engineer and found to be serviceable :</p> <p>Car Enclosure and COP Emergency Alarm System Indicators and Call Buttons Floor Levels and Selector Machine and Brake Controller and Drive Overspeed Devices Operation of Car Doors Car Top Door and Gate Check Shaft Equipment Pit and Underside of Car</p>		<p>door operator needs setting up once builders have finished works. changed fan wiring should be separate from car lighting pit ladders required for both lifts and barriers lg1 visit</p>								
		<table border="1"> <tr> <td>Total Time on Site</td> <td>2.00</td> </tr> <tr> <td>Total Travel to Site</td> <td>0.00</td> </tr> </table>		Total Time on Site	2.00	Total Travel to Site	0.00			
Total Time on Site	2.00									
Total Travel to Site	0.00									
<table border="1"> <tr> <td>Signature Declined</td> <td>N</td> </tr> <tr> <td>Decline Reason</td> <td></td> </tr> </table>		Signature Declined	N	Decline Reason		<table border="1"> <tr> <td>Customer Name</td> <td rowspan="2">Customer Unavailable For Signature</td> </tr> <tr> <td>Signed Date & Time</td> </tr> </table>		Customer Name	Customer Unavailable For Signature	Signed Date & Time
Signature Declined	N									
Decline Reason										
Customer Name	Customer Unavailable For Signature									
Signed Date & Time										
Attending Engineer(s)										
Engineer Name	Date Attended	Site Arrival	Site Depart							
Time on site	Travel to site	Customer Signoffs								
A Smart (58579)	12/04/17	12:00	14:00							
	2.00	0.00	N/A							

Service Visit Report



Job Number	PD807175	Customer Order Number				
Unit Number	PD807175	Parts Used				
Site Address	Grenfell Tower Grenfell Road London W11 1TG					
Unit Reference	H091					
Date of Service Visit Report	31/05/2017					
Visit Type	S					
Works Completed	<p>As part of the scheduled maintenance visit, the below items were checked by our engineer and found to be serviceable :</p> <ul style="list-style-type: none"> Car Enclosure and COP Emergency Alarm System Indicators and Call Buttons Floor Levels and Selector Machine and Brake Controller and Drive Overspeed Devices Operation of Car Doors Car Top Door and Gate Check Shaft Equipment Pit and Underside of Car 					
	<p>Observations</p> <p>. changed fan wiring should be separate from car lighting pit ladders required for both lifts and barriers</p>					
	Total Time on Site	2.00				
	Total Travel to Site	0.00				
Signature Declined	N	Customer Name	Customer Unavailable For Signature			
Decline Reason		Signed Date & Time				
Attending Engineer(s)						
Engineer Name	Date Attended	Site Arrival	Site Depart	Time on site	Travel to site	Customer Signoffs
A Smart (58579)	09/05/17	15:00	17:00	2.00	0.00	N/A