

**To:** Hugh Mahoney[hm@psbuk.com]; Richard Midgley[rm@wittandson.co.uk]  
**Cc:** Bob Hill[Bob.Hill@psbuk.com]  
**From:** Andy Bridges  
**Sent:** Thur 18/02/2016 11:40:04 AM  
**Subject:** RE: Grenfell Tower London W11

Thanks hugh,

I spoke to Richard yesterday evening, I'm getting JSW to sort it out.

Regards

Andy

Andy Bridges

R J ELECTRICS LTD 28 MANOR RD DAGENHAM ESSEX RM10 8AU

T: [REDACTED] F: [REDACTED] D: [REDACTED] M: [REDACTED] E: andy@rjelectrics.co.uk

---

**From:** Hugh Mahoney [mailto:hm@psbuk.com]

**Sent:** 18 February 2016 10:55

**To:** Andy Bridges; Richard Midgley

**Cc:** Bob Hill

**Subject:** RE: Grenfell Tower London W11

Hi All,

The smoke control system does not have the requirement for dial up, as this is not a requirement of the smoke control specification for the project.

Regards

**Hugh Mahoney**  
Technical Sales Manager

**PSB UK Ltd**

Witt House  
Shelf Mills  
Shelf  
Halifax  
HX3 7BJ  
England

Tel: [REDACTED]  
Fax: [REDACTED]  
Mob: [REDACTED]

If you are an unauthorised recipient of this email, you are requested to preserve the identity of it and advise the sender immediately of any error in transmission. Any disclosure, copying, distribution or action taken, or omitted to be taken, by an unauthorized recipient in reliance upon the contents of this e-mail is prohibited and may be unlawful. You should carry out your own virus checks before opening any attachment. The contents of any attachment may contain software viruses which could damage your own computer system. While the Witt UK Group has taken every reasonable precaution to minimise this risk, we cannot accept liability for any damage which you may sustain as a result of software viruses. Please note that in replying to this e-mail you are granting the right for that reply to be forwarded to any other individual within the business and externally and to be read by others, for instance in the event that the intended recipient is out of the office or is no longer employed by us.

---

**From:** Andy Bridges [mailto:andy@rjelectrics.co.uk]

**Sent:** 17 February 2016 17:15

**To:** Richard Midgley <rm@wittandson.co.uk>

**Cc:** Hugh Mahoney <hm@psbuk.com>

**Subject:** Grenfell Tower London W11

Hi Richard,

I had a query from our Client yesterday, to which I wonder if you could help. He asked how the dial up facility from your main panel worked. This is appertaining to asking the building owners how they wish the dial up to work within their organisation etc.

Apologies if I haven't been clear here. By all means give me a call and we can discuss.

Regards

Andy

PSB00000991\_0001

PSB00000991/1

Andy Bridges

R J ELECTRICS LTD 28 MANOR RD DAGENHAM ESSEX RM10 8AU

T: [REDACTED] F: [REDACTED] D: [REDACTED] M: [REDACTED] E: [andy@rjelectrics.co.uk](mailto:andy@rjelectrics.co.uk)