

Message

---

**From:** Hoban, John: PC-Plan [john.hoban@rbkc.gov.uk]  
**Sent:** 18/11/2014 09:04:12  
**To:** Neil Crawford [neil@studioe.co.uk]  
**CC:** Hanson, Paul: PC-Plan [paul.hanson@rbkc.gov.uk]  
**Subject:** Grenfell Tower, Grenfell Road Regeneration Project MOE Obs Submission 1 Revised 2  
**Attachments:** MOE Obs Grenfell Tower, Grenfell Road S1.docx; RBKC MOE Plan Grenfell Tower, Grenfell Road Ground floor 1279 SEA (08) 100b - Fire Access-A1-000 S1.pdf; RBKC MOE Plan Grenfell Tower 1279 SEA (08) 101b - Fire Strategy-A1-000 S1.pdf

Dear Neil,

The Building Regulations 2010 (as amended)  
Grenfell Tower, Grenfell Road.

Thank you for your submission S1 for the above project.

A decision notice will be forwarded to you shortly on the proposals submitted.

As you have mentioned both Paul Hanson and myself have commented upon the scheme at preliminary stage which we identified as P1 and P2 submissions. Observations from Paul on the means of escape and fire fighting access for this submission are attached with marked up plans identified as S1.

As you have recently taken over the project I felt it would also be useful to highlight the most significant points below. They are also described in more detail in the observations and marked up on the plans.

**Revisions to preliminary scheme:-**

1. The revised residential use at walkway level opens directly into the stairway without a ventilated lobby – the plans have been marked up with a suggestion, to add a lobby.
2. Natural ventilated lobbies to non residential accommodation – the alterations to the scheme do not appear to have included the need for 0.4m<sup>2</sup> ventilated lobbies to the revised central connection from the single residential stairway to the boxing club at Walkway and office use at Ground levels.

**Significant matters outstanding from preliminary scheme**

3. The extract rate for the existing residential stairway lobby's to the newly extended residential units still needs to be justified by the design team.
4. The access to riser shafts directly into the single stairway need to be avoided (any shaft connection to the green areas) on the plans marked A).
5. The building regulations deal with the building work proposed in an existing building and are limited to ensuring that no adverse affect takes place to any exiting situation. Your client does however have an overriding responsibility to provide adequate fire safety for the existing building under a separate piece of legislation called the Regulator Reform (fire safety) Order 2005 (RRO), which may involve upgrading the exiting building. At preliminary meetings the design team had highlighted a concern whether any refurbishment of the mechanical stairway lobby ventilation system would be suitable for the purpose of the RRO.

The design team asked whether RBKC could assist by consulting the fire authority regarding their views under the Regulatory Reform Fire safety order in respect of the lobby ventilation system. RBKC can pass on any letter explaining your questions directly to the fire authority. RBKC's observations on submission P2 outlined the recommended information you should prepare which

RBKC would submit to the fire authority on your behalf. If you still wish this to take place please submit your letter for the fire authority explaining your concerns and questions including details of the proposed ventilation system for us to pass on to the fire authority.

For the purpose of submission S1 we will consult the fire authority under the building regulations in the normal way but it is important to understand that this consultation only relates to the new building work taking place and will give not reassurance to your client regarding how the existing building will be considered under the ongoing controls of the Regulatory reform (fire safety) order.

A meeting has been arranged for next Monday morning at the site, to discuss the smoke ventilation system to the lobbies of the building. It may be useful to distribute the attached observations and plans to the design team as appropriate.

Best regards,

John Hoban  
**John Hoban**  
Senior Building Control Surveyor

  
[john.hoban@rbkc.gov.uk](mailto:john.hoban@rbkc.gov.uk)

*This e-mail may contain information which is confidential, legally privileged and/or copyright. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.*

**From:** Neil Crawford [<mailto:Neil@studioe.co.uk>]  
**Sent:** 29 September 2014 16:37  
**To:** Hoban, John: PC-Plan  
**Cc:** [slawrence@rydon.co.uk](mailto:slawrence@rydon.co.uk); 1279 Grenfell Tower; Hanson, Paul: PC-Plan  
**Subject:** RE: Grenfell Tower Regeneration Project

John

Please see attached the current Exova Study which was written prior to the Fire Strategy Rev B changes and also attached the correspondence with Exova relating to the Rev B changes which we will modify accordingly.

Regards  
Neil

**From:** Neil Crawford  
**Sent:** 24 September 2014 16:30  
**To:** [john.hoban@rbkc.gov.uk](mailto:john.hoban@rbkc.gov.uk)  
**Cc:** [slawrence@rydon.co.uk](mailto:slawrence@rydon.co.uk); 1279 Grenfell Tower; [Paul.Hanson@rbkc.gov.uk](mailto:Paul.Hanson@rbkc.gov.uk)  
**Subject:** Grenfell Tower Regeneration Project

John

Following our conversation on site whilst looking at the Academy on Tuesday, I am forwarding a pack of drawings for the Grenfell Tower Project as mentioned.

I believe yourself and Paul Hanson sat down earlier in the year and did an initial appraisal of the proposed layout changes to the lower levels with Bruce Sounes from our office. I have included Pauls initial mark-ups of the fire strategy from this time as well as a new set which shows that there has been some simplification to the arrangement on these floors. I know you like to go through the drawings on an agreed process of release rather than just being swamped with everything at once so I am just sending the following drawings to start with;

- Fire strategy drawings from previous meeting with Paul Hanson's mark up  
1279 SEA (08) 100 - Fire Access  
1279 SEA (08) 101 - Fire Strategy
- New fire strategy drawings that show modifications to office area and omission on internal office stair  
1279 SEA (08) 100b - Fire Access-A1-000  
1279 SEA (08) 101b - Fire Strategy-A1-000
- Basic Plans sections and elevations GA set  
1279 SEA (06) 100 - Section A  
1279 SEA (06) 100 - Section A  
1279 SEA (06) 100 - Section A  
1279 SEA (06) 100 - Section A  
1279 SEA (06) 100 - Section A  
1279 SEA (05) 100 - Proposed South Elevation Rev01  
1279 SEA (05) 101 - Proposed North Elevation Rev01  
1279 SEA (05) 102 - Proposed East Elevation Rev01  
1279 SEA (05) 103 - Proposed West Elevation Rev01  
1279 SEA (04) 100 - Proposed Basement Plan  
1279 SEA (04) 101 Rev01 - Proposed Ground Floor Plan  
1279 SEA (04) 102 Rev01- Proposed Mezzanine Plan.pdf  
1279 SEA (04) 103 Rev01 - Proposed Walkway Plan.pdf  
1279 SEA (04) 105 - Proposed Residential Plan (W+2)  
1279 SEA (04) 108 - Proposed Roof Plant Plan  
1279 SEA (04) 109 - Proposed Roof Plan

Regards

Neil

**Neil Crawford**

Associate

For and on behalf of

**STUDIO E LTD**

Unit 310 Linton House, 164/180 Union Street, London, SE1 0LH

T [REDACTED] | [www.studioe.co.uk](http://www.studioe.co.uk)



**Queen's Award for Enterprise: Sustainable Development 2010**

BCSE Award School Architect of the Year 2008 & 2010

BCSE Award Inspiring Design Primary School 2008 & Academy 2010

BSF Award Excellence in Student Engagement 2009

Sustainable City Award 2009



Please consider the environment before printing this email.

**ELECTRONIC INFORMATION TRANSFER DISCLAIMER**

This email and any files transmitted with it are sent for and on behalf of Studio E LLP and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender. All attached files are copyright and may only be used for the purpose stated in the drawing status box. In the event that the files are altered in anyway, it is a condition of use that the Studio E name and logo be removed from the modified file, unless prior written agreement has been obtained. Studio E will assume no responsibility for the accuracy, adequacy, and integrity of the files, and recommends that the files be thoroughly screened for viruses prior to installation. Opinions, conclusions and other information expressed in this message are not given or endorsed by Studio E LLP unless otherwise indicated by an authorized representative independent of this message.