

MEMORANDUM

To: John Hoban
cc:

From: Paul Hanson
Dated: 24/6/2015

B1 - MEANS OF ESCAPE OBSERVATIONS

PREMISES: Grenfell Tower, Grenfell Road
APP No: Submission 1a
SUBMISSION No: S1a
DOCUMENTS: J S Wright & Co Limited
Smoke Ventilation Technical submission PSBUK1143-12 rev 3 12th June 2015

I make the following comments using Approved Document B and, where appropriate, BS 9991.

Comments to client

Powered ventilation system serving single stairway lobbies

The proposals outlined in the Smoke Ventilation Technical submission PSBUK1143-12 rev 3 are satisfactory.

1. I note that there is the intention to bring the ventilation system down to also serves the existing ground level lobby adjacent to the lifts and switch room.
2. Final details of the key switch arrangements should be submitted when finalised.
3. Generally the components of the system should conform to the Guidance on Smoke Control to Common Escape Routes in Apartment Buildings (Flats and Maisonettes) Revision 1: June 2012 listed in section 11.3.