

Message

From: Hanson, Paul: CP-Plan ["/o=exchange/ou=town hall/cn=recipients/cn=plnpdh"]
Sent: 24/06/2015 14:14:16
To: Neil Crawford [neil@studioe.co.uk]
CC: Hoban, John: CP-Plan [john.hoban@rbkc.gov.uk]
Subject: Grenfell Tower Regeneration Project - Ground floor store room
Attachments: RBKC MOE Plan Grenfell Tower, Grenfell Road Ground floor 1279 SEA (08) 100b - Fire Access-A1-000 S1a.pdf

Hi Neil,

Whilst considering the mechanical smoke vent submission, I noticed on the plans that there is a store room at ground level which opens directly into the stairway at ground level. We had previously discussed the need to provide lobby protection to all stair connections. Looking at the last set of submitted plans this unlobbied arrangement was indicated, but I had not identified this.

Therefore I thought I should draw your attention to this as the store room should open into the lobby. See attached plan with the blue clouded area.

Apologies that this was not identified at the time.

If you need to discuss this further please do not hesitate to ring me.

Regards.

Paul Hanson
Senior Building Control Surveyor (Fire Regulations)
Royal Borough of Kensington and Chelsea
T. [REDACTED]
M. [REDACTED]
F. [REDACTED]
W. www.rbkc.gov.uk/buildingcontrol

View the latest video covering the [Holland Park School Redevelopment](#)

Building Control media and publications are available by clicking on the following link:- [Publications](#)