

Message

From: Anon, Jose: PC-Plan ["/o=exchange/ou=town hall/cn=recipients/cn=plnjma"]
Sent: 17/04/2015 09:45:17
Subject: Grenfell Tower, Grenfell Road

FP/14/03563
Grenfell Tower, Grenfell Road
Jason North [REDACTED]
site visit

Metal deck in place, A393 Mesh going in and ok, min cover 25 mm to mesh. Overlaps ok.