

Message

---

**From:** Anon, Jose: PC-Plan ["/o=exchange/ou=town hall/cn=recipients/cn=plnjma"]  
**Sent:** 17/04/2015 09:45:17  
**Subject:** Grenfell Tower, Grenfell Road

FP/14/03563  
Grenfell Tower, Grenfell Road  
Jason North [REDACTED]  
site visit

Metal deck in place, A393 Mesh going in and ok, min cover 25 mm to mesh. Overlaps ok.