

Director of Architecture
Superintending Architect of
Metropolitan Buildings
Peter Jones FRIBA FRTPI

Middlesex House
20 Vauxhall Bridge Road London SW1V 2SB

Messrs Dunbar & Boardman Partnership
The Studio
63-67 Tabernacle Street
EC2A 2AH

Telephone [REDACTED]

Telex [REDACTED]

Please reply to

Mr B. G. Roberts

My reference

AR/BR/2/150917

Your reference

PGB/EP/83147

Date

10.4.84

DISTRICT Surveyor

Dear Sirs,

Kensington

LONDON BUILDING ACTS (AMENDMENT) ACT 1939 - SECTIONS 20 AND 34
GRENfell TOWERS, LANCASTER ROAD, KENSINGTON, W8

With reference to your letter dated 8 February 1984, I confirm that in this instance the lift doors are required to be not less than one half hour standard of fire-resistance.

Yours faithfully,

PETER JONES

PER L7

Superintending Architect

