
From: Simon O'Connor
Sent: 16 January 2015 15:32
To: Alan Grint
Subject: FW: cladding rattling

FYI

Can you please chase this up on Monday.

Regards

Simon O'Connor, ACIOB, M InstLM
Project Manager

T [REDACTED]
D [REDACTED]

From: Simon O'Connor
Sent: 16 January 2015 15:22
To: 'Rob Maxwell'
Cc: Simon Lawrence
Subject: FW: cladding rattling

Rob,

We will need you to investigate this allegation and put together a professional and accurate response to this as soon as possible.

Regards

Simon O'Connor, ACIOB, M InstLM
Project Manager

T [REDACTED]
D [REDACTED]

From: Claire Williams [mailto:clwilliams@kctmo.org.uk]
Sent: 16 January 2015 15:13
To: Simon Lawrence
Cc: Simon O'Connor; Peter Maddison
Subject: FW: cladding rattling

Simon

Can I please have a formal response to the comments below by end of play on Monday 19 Jan?

I know that Simon O'Connor had had Harley check on 15 January that all was well, but I do not need to have any misinformation out there about the fixings to Grenfell which would undermine confidence in the project.

Thank you.

Claire Williams
Project Manager



t: [REDACTED]
m: [REDACTED]
a: The Network Hub, 292a Kensal Road, London, W10 5BE
 Before printing, please think about the environment

From: [REDACTED]
Sent: 16 January 2015 15:05
To: Claire Williams; Peter Maddison
Subject: RE: cladding rattling

hello clare,

they should not be blaming the high wind.
they have been plainly negligent . the frames were loose as probably the fasteners were not tightened properly.
their specialist sub-contractors have tightened them but looking at the frame below my window I can see some of the anchors
bolts are too short. the nuts on them are sitting right on end/edge of the bolt with no threads visible.
this is plainly wrong. ask any expert(and you should!) and they will tell you it is wrong. the question is how many of the fixings are like that.
how much of a problem are we storing for the long term?
The question needs to be addressed now and not after the panels have been fixed.

i hope you will raise these points with rydon and come up with a solution.

regards

spatel

From: clwilliams@kctmo.org.uk
To: [REDACTED]
Subject: cladding rattling
Date: Thu, 15 Jan 2015 17:11:05 +0000

Mr Patel

I apologise, but the contractor has responded to me, but not given me a chance to get the notice put up.

Essentially they had their specialist sub-contractor check all the work, and nothing is loose or un-fixed. However they noted that the wind speeds were very high last night and that this impacted on the angles that have been fixed to date.

The winds should have subsided now, and ultimately the angles that were ‘rattling’ will be tightly fixed to the new cladding so this should not be an issue with the final installation.

I apologise for the noise that must have been very unsettling to all concerned.

Claire Williams
Project Manager



t: [REDACTED]
m: [REDACTED]

a: The Network Hub, 292a Kensal Road, London, W10 5BE

Before printing, please think about the environment

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.

This e-mail message has been scanned for Viruses and Content and cleared by **MailMarshal**

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should

not disseminate, distribute
or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd. Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>
