
From: M.Smith@maxfordham.com
Sent: 14 April 2016 16:11
To: Steve Blake
Cc: d.campbell@maxfordham.com; Claire Williams; Niel Reed; MALCOLM Andrew; Alan Whyte; David Hughes; Batty,Tony; jon white (jwhite@jrp.co.uk)
Subject: Grenfell - Fire alarm

Afternoon Steve

I've discussed your queries regarding the fire alarm with Adrian Brown from Exova who has now replaced Terry Ashton (adrian.brown@exova.com).

1. He has suggested that the boilers - both new and old - could be interlinked with a standalone fire alarm system in the basement rather than with the AOV system to avoid the nuisance tripping which has been occurring,
2. He has suggested that the door entry system should allow fireman's access either via drop switches or by connecting to the fire alarm system. If drop switches are used then the correct type should be checked with the local fire brigade.

If you have any further queries please contact him directly.

Kind regards,

Matt

MAX FORDHAM / 50

42-43 Gloucester Crescent

London

NW1 7PE

T [REDACTED]

maxfordham.com

@maxfordhamLLP

Max Fordham LLP is a Limited Liability Partnership. Registered in England and Wales Number OC300026
Registered office 42-43 Gloucester Crescent, London, NW1 7PE

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit <http://www.symanteccloud.com>
