

Message

From: David Bradbury [DavidBradbury@jswright.co.uk]
Sent: 03/09/2014 08:06:11
To: Paul.Hanson@rbkc.gov.uk; 'John.hoban@rbkc.gov.uk'
CC: Robin Thorne [robinthorne@jswright.co.uk]; Alan Whyte [AlanWhyte@jswright.co.uk]; Simon Lawrence [slawrence@rydon.co.uk]; Simon O'Connor [SOConnor@rydon.co.uk]; Neil Crawford [Neil@studioe.co.uk]; Bruce Sounes [bruce@studioe.co.uk]; Terence McLaughlin [terencemclaughlin@jswright.co.uk]
Subject: FW: Grenfell Tower

Morning Paul,

I sent a message to John Hoban yesterday regarding the dry riser at Grenfell Tower, however I've been informed you may be the person to speak to regarding fire issues?

Kind regards,

Dave Bradbury
Senior Design Engineer

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: davidbradbury@jswright.co.uk | Web: www.jswright.co.uk

From: David Bradbury
Sent: 02 September 2014 15:59
To: 'John.hoban@rbkc.gov.uk'
Cc: Terence McLaughlin; Robin Thorne; Alan Whyte; 'Simon Lawrence'; Simon O'Connor; 'Neil@studioe.co.uk'; 'Bruce Sounes'
Subject: Grenfell Tower

Hi John,

Simon Lawrence from Rydon has passed on your details, I'd like to introduce myself as I am currently working on the refurbishment of the above mentioned project. We will be carrying out the mechanical and electrical works associated with the refurbishment.

One of the items I need to discuss with you is the modifications to the existing dry riser. We are not increasing the high of the existing riser but we are adding two additional floors at low level which were previously walkways. We understand the existing riser is above the current permitted height of 50 meters, we would therefore need to discuss the proposed modification and what measures we need to take to gain approval for the new system.

I have tried to call but I understand you are currently out of the office, please call me when you can on the number below, alternatively I will try calling again tomorrow morning. Thank you.

Kind regards,

Dave Bradbury
Senior Design Engineer

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: davidbradbury@jswright.co.uk | Web: www.jswright.co.uk

HOTEL

LEISURE

COMMERCIAL

STUDENT
ACCOMMODATION

RESIDENTIAL

CARE HOMES



PAS99
ISO 9001
ISO 14001
OHSAS 18001

LOW CARBON CONSULTANTS



**One of the Leading Mechanical & Plumbing Design & Installation Companies in the UK
Winners of the H&V Award for "Outstanding Contribution to the Industry 2013"**

Head Office - J S Wright & Co Ltd, The Atlas Building, 16 Portland Street, Aston, Birmingham, B6 5RX
London Office - J S Wright & Co Ltd, 1 Northumberland Avenue, London, WC2N 5BW Tel: [REDACTED]

The contents of this email and any attachments are the property of J S Wright & Co Limited and are for the confidential use of the named recipient(s) only. They may be legally privileged and should not be communicated to or relied upon by any person without our express written consent. If you are not an addressee please notify us immediately at <mailto:jswright@jswright.co.uk> Any files attached to this email will have been checked with virus detection software before transmission. However, you should carry out your own virus check before opening any attachment. J S Wright & Co Limited accepts no liability for any loss or damage which may be caused by software viruses.



Please Consider the Environment before Printing this E-mail