

Message

**From:** Neil Crawford [/O=STUDIO E/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=NEIL]  
**Sent:** 23/02/2015 16:10:24  
**To:** john.hoban@rbkc.gov.uk; Paul.Hanson@rbkc.gov.uk  
**Subject:** Grenfell Tower- Revisions to Fire Strategy Drawings  
**Attachments:** 1279 SEA (08) 101 Rev 04- Fire Strategy with comment.dgn.pdf; 1279 SEA (08) 100 Rev 05 - Fire Access with comment.dgn.pdf

John

Please see attached Grenfell Tower fire strategy drawings with two queries marked on in red boxes as follows;

- 1) Drawing 1279 (08) 100 Rev 05 The door on Ground Floor to the lift lobby can this be FD30S (half wall rating)?
- 2) Drawing 1279 (08) 101 Rev 04 Can the doors to the new apartments be FD30S or do these need to be FD60S as advised previously?

I look forward to your response,

Regards  
Neil

**Neil Crawford**  
Associate

For and on behalf of

**STUDIO E ARCHITECTS LTD**

Unit 310 Linton House, 164/180 Union Street, London, SE1 0LH  
T [REDACTED] | [www.studioe.co.uk](http://www.studioe.co.uk)



**Queen's Award for Enterprise: Sustainable Development 2010**  
BCSE Award School Architect of the Year 2008 & 2010  
BCSE Award Inspiring Design Primary School 2008 & Academy 2010  
BSF Award Excellence in Student Engagement 2009  
Sustainable City Award 2009



Please consider the environment before printing this email.

**ELECTRONIC INFORMATION TRANSFER DISCLAIMER**

This email and any files transmitted with it are sent for and on behalf of Studio E LLP and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender. All attached files are copyright and may only be used for the purpose stated in the drawing status box. In the event that the files are altered in anyway, it is a condition of use that the Studio E name and logo be removed from the modified file, unless prior written agreement has been obtained. Studio E will assume no responsibility for the accuracy, adequacy, and integrity of the files, and recommends that the files be thoroughly screened for viruses prior to installation. Opinions, conclusions and other information expressed in this message are not given or endorsed by Studio E LLP unless otherwise indicated by an authorised representative independent of this message.