
From: Daniel Anketell-Jones
Sent: 26 August 2014 17:06
To: Neil Crawford
Cc: Kevin Lamb; slawrence@rydon.co.uk; Bruce Sounes; 1279 Grenfell Tower
Subject: Re: Grenfell Tower Preliminary cladding drawings for comment

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: 1279 Grenfell

Neil,

Unfortunately there isn't a meeting tomorrow. However, we still need to bottom out these details, which will allow us to start ordering material. Can I suggest, that you and Kevin speak on the phone tomorrow, and iron out these details?

Then we can resubmit, and perhaps even get them approved before the next meeting (time and date to be advised).

Do you have a number we can contact you on? Your landline number doesn't seem to be working at the moment?

Kind Regards

Daniel

On 26 Aug 2014, at 15:45, "Neil Crawford" <Neil@studioe.co.uk> wrote:

Hi Kevin

Ahead of returning marked up comments on your preliminary drawing set I have made some observations which perhaps we could discuss at some point during tomorrow's DTM?

- Vertical detail 1/304 the column panel is shown in panels corresponding to the column facets. I can see the practicality of this given panel press limitations however I think the 45mm gap on the corner will look odd as an open joint given its expressed nature- the hanging bars are likely to be very obvious(?)
- Vertical detail 1/305 is shown as a smaller joint rather than a 45mm joint which would be subject to the same issues raised above.
- Cill detail 1/300- a lot of fixings. If the cill flashing were to extend as a drip detail over the rain screen panel the lower set of fixings could be removed(?)

Regards
Neil

From: Kevin Lamb [<mailto:KevinLamb@harleycw.co.uk>]
Sent: 22 August 2014 20:49
To: slawrence@rydon.co.uk

Cc: Daniel Anketell-Jones; Neil Crawford; Bruce Sounes
Subject: Grenfell Tower

Simon,

Please find attached some preliminary drawings to prove the basics of design & set out, prior to us producing a full design package.

It would be useful for us to discuss these principles at our meeting on Tuesday morning.

Regards

Kevin Lamb
Project Designer

<image001.jpg>

T-
F-

W- www.harleycurtainwall.com

Head Office

Harley House, Brooklands Park
Farningham Road, Crowborough
East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.