
From: Neil Crawford
Sent: 24 September 2014 12:28
To: Kevin Lamb; slawrence@rydon.co.uk
Cc: Daniel Anketell-Jones; Bruce Sounes; 1279 Grenfell Tower
Subject: RE: Grenfell Tower
Attachments: 140924 Preliminary Drwaing Comments.pdf; Re: Grenfell Tower Regeneration Scheme

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: 1279 Grenfell

Hi Kevin/ Simon

Following yesterdays review of the cladding drawings please find attached marked up drawings. I have checked with Bruce on a number of the issues raised;

- The number of opening windows should stay as drawn in the planning drawings. The narrow opening lights are intended to be used as purge openings with the larger windows opening to facilitate cleaning.
- The horizontal column panel joint should also be 45mm with the recess depth lining through with the vertical joints- please see marked up drawings the 45mm expression to be kept on vertical interface of column to flat cladding also.
- I have checked with Max Fordham in relation to the trickle vent requirements the response of which I have attached. Nothing has been mentioned about air leakage or glass G-values so I have sought clarification on this also (Presumably the air leakage is not so bad [whistling issues] that it could be used in lui of the trickle vents).

Regards
Neil

From: Kevin Lamb [<mailto:KevinLamb@harleycw.co.uk>]
Sent: 22 September 2014 16:08
To: slawrence@rydon.co.uk
Cc: Daniel Anketell-Jones; Neil Crawford; Bruce Sounes
Subject: Grenfell Tower

Simon,

Please find attached drawings as raised in issue for final approval, based upon the Architects comments and discussions at our last meeting.

We shall shortly issue further details, for consideration.

Regards

Kevin Lamb
Project Designer



T- [REDACTED]
F- [REDACTED]
W- www.harleycurtainwall.com

Head Office

Harley House, Brooklands Park
Farningham Road, Crowborough
East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.

Regards

Kevin Lamb

If you have any queries regarding this email, please do not hesitate to contact us:

Bespoke Design



Tel [REDACTED]