
From: Kevin Lamb
Sent: 25 September 2014 17:28
To: slawrence@rydon.co.uk
Cc: Daniel Anketell-Jones; Neil Crawford; Bruce Sounes
Subject: Grenfell Tower
Attachments: 855 C1059 Grenfell Tower Register.pdf; 855 C1059 GA Model 09.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: 1279 Grenfell

Simon,

Please find attached drawings revised, where practical, in accordance with our discussions at the last meeting and Architects comments from yesterday.

- We need confirmation from Rydons as to your required panel size to the louvred units in the kitchen windows.

Neil,

Just a few notes on your commented drawings that you need to consider and action if not agreeable:

1. You have noted on drg 200 that the East & West elevations are rotated not mirrored, however our elevation showed the louvre unit to the wrong side, as discussed on Tues.
2. We had also shown the louvre incorrectly on drg 201.
3. You require the joint infill piece to the column cladding rather than the spandrel (drg 305), however we feel that this will not allow us to close off nicely. See our new drg 312. The cill cannot be used to close the tolerance gap, covering the infill as there would no longer be a tolerance gap!
4. Further to your email from Matt of Max Fordham, the requirements for trickle ventilation do not appear explicit and we would suggest that you consider the values that we have shown on the elevations and advise whether more or less are required. To improve what we have up to 5000mm², the vents will have to be increased in width by 40-50mm. There is also a suggestion that lower level venting may be required, so please confirm if & where you would like this.

Regards

Kevin Lamb
Project Designer



T- [REDACTED]
F- [REDACTED]
W- www.harleycurtainwall.com

Head Office
Harley House, Brooklands Park
Farningham Road, Crowborough
East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.

Regards

Kevin Lamb

If you have any queries regarding this email, please do not hesitate to contact us:

Bespoke Design



Tel 