
From: Neil Crawford
Sent: 06 March 2015 15:46
To: Kevin Lamb; slawrence@rydon.co.uk; Simon O'Connor (SOConnor@rydon.co.uk)
Cc: Daniel Anketell-Jones; Mark Stapley; Ben Bailey; Rob Maxwell
Subject: RE: Grenfell
Attachments: 150306 Walkway+1 SEA drawing comment.pdf

Hi Kevin

Please see attached drawing comments on the Walkway +1 drawings.
I think the need to keep the small windows at the bottom on all facades for this level as the clearance to floor line in marginal (~800mm)- see comments

Regards
Neil

From: Kevin Lamb [<mailto:KevinLamb@harleycw.co.uk>]
Sent: 03 March 2015 17:45
To: slawrence@rydon.co.uk
Cc: Neil Crawford; Bruce Sounes; Daniel Anketell-Jones; Mark Stapley; Ben Bailey; Rob Maxwell
Subject: Grenfell

Simon,

Please find attached drawings for the W+1 level, all raised to construction status, except 100, 206 & 328.

Please comment on 206 ASAP as we can manufacture these accordingly.

Regards

Kevin Lamb
Project Designer



T- [REDACTED]
F- [REDACTED]
W- www.harleycurtainwall.com

Head Office
Harley House, Brooklands Park
Farningham Road, Crowborough
East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.