
From: John.Hoban@rbkc.gov.uk
Sent: 20 March 2015 13:22
To: Neil Crawford; Paul.Hanson@rbkc.gov.uk
Cc: slawrence@rydon.co.uk; KevinLamb@harleycw.co.uk; SOConnor@rydon.co.uk; jnorth@rydon.co.uk
Subject: RE: Grenfell

Dear Neil,

The Building Regulations 2010 (as amended)
Grenfell Tower, Grenfell Road, Refurbishment.

Thank you for returning my call this morning.

Further to my conversation with you today, I would confirm that the *fire time* for the new *Elements of Structure* [new columns, beams, sections of compartment floor etc.] in Grenfell Tower is 120 minutes, as specified in section 1a of Table A2, Appendix A of Approved Document B.

I would also draw your attention to diagram 33 of Approved Document B and highlight the detail between compartment floors and external cladding. In the meantime should you wish to discuss any other aspects of the project Neil, then please do not hesitate to call me, my direct line contact number is [REDACTED]

Best regards,

John Hoban
John Hoban
Senior Building Control Surveyor
[REDACTED]
john.hoban@rbkc.gov.uk

This e-mail may contain information which is confidential, legally privileged and/or copyright. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.

From: Neil Crawford [<mailto:Neil@studioe.co.uk>]
Sent: 06 March 2015 15:50
To: Hanson, Paul: PC-Plan
Cc: Hoban, John: PC-Plan; slawrence@rydon.co.uk; Kevin Lamb (KevinLamb@harleycw.co.uk); Simon O'Connor (SOConnor@rydon.co.uk); Jason North (jnorth@rydon.co.uk)
Subject: FW: Grenfell

Hi Paul

Following our conversation this afternoon, this reminded me of another issue. Where we are over cladding what fire rating do we need to allow for within the wall build up between apartments (see below and attached)?

Regards
Neil

From: Kevin Lamb [<mailto:KevinLamb@harleycw.co.uk>]
Sent: 03 March 2015 12:58
To: slawrence@rydon.co.uk
Cc: Neil Crawford; Bruce Sounes; Daniel Anketell-Jones; Mark Stapley; Rob Maxwell; Ben Bailey
Subject: Grenfell

Simon,

Please find attached drawings now showing the fire breaks, both horizontal and vertical.

We assume a requirement of 90min integrity & 30min insulation is sufficient, if not please advise.

The vertical breaks are not on all columns, just party walls.

Regards

Kevin Lamb
Project Designer



T- [REDACTED]
F- [REDACTED]
W- www.harleycurtainwall.com

Head Office
Harley House, Brooklands Park
Farningham Road, Crowborough
East Sussex, TN6 2JD

Email Disclaimer:

This email has been sent by Harley Curtain Wall Ltd. The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Any views expressed in this message, are those of the individuals sender, except where the sender specifically states them to be the views of Harley Curtain Wall Ltd. Whilst Harley Curtain Wall Ltd takes reasonable precautions to scan email content for viruses, we cannot give warranties or assurances about the safety and contents of this email including any attachments herewith. It is the responsibility of the recipient to scan the email and any attachments herewith sent for malicious content.

Basement development consultation: If you would like to comment on the Council's new draft Supplementary Planning Document on Basements you can do so until Wednesday 1 April.

To have your say go to <http://www.rbkc.gov.uk/basementconsult>

Are you registered to vote? The deadline to register to vote for the UK Parliamentary election is Monday 20 April 2015.

You can register to vote at <http://www.gov.uk/registertovote>

The Royal Borough of Kensington and Chelsea.
This e-mail may contain information which is confidential,
legally privileged and/or copyright protected. This e-mail

is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.
