
From: David Bradbury
Sent: 08 May 2015 14:24
To: M.Smith@maxfordham.com; Neil Crawford
Cc: David Peacock; d.campbell@maxfordham.com; richard moss; Simon Lawrence; Simon O'Connor
Subject: RE: Grenfell Tower Kitchen Window Fan
Attachments: Fan Data Sheet_CYFAN-C I&M.PDF; Fan Data Sheet_CYFAN-WKIT.pdf

Thanks Matt.

Neil, please email below and attachments regarding the kitchen extract fans, can you let me have any comments please.

Rich, I've just got your message confirming Rydons have said the fascia board thickness does not exceed 32mm. thanks.

Kind regards,

Dave Bradbury
Design Manager
Head Office

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: davidbradbury@jswright.co.uk | Web: www.jswright.co.uk

From: M.Smith@maxfordham.com [mailto:M.Smith@maxfordham.com]
Sent: 08 May 2015 13:55
To: David Bradbury
Cc: David Peacock; d.campbell@maxfordham.com; richard moss; Simon Lawrence; Simon O'Connor
Subject: Re: Grenfell Tower Kitchen Window Fan

Afternoon Dave

The only comment from me would be to ensure that Studio E have been kept in the loop regarding colour/integration with the facade system.

Kind regards,

Matt

MAX FORDHAM
42-43 Gloucester Crescent
London
NW1 7PE
T: [REDACTED]
F: [REDACTED]
maxfordham.com

From: David Bradbury <DavidBradbury@jswright.co.uk>
To: Simon Lawrence <slawrence@rydon.co.uk>, "M.Smith@maxfordham.com" <M.Smith@maxfordham.com>
Cc: Simon O'Connor <SOConnor@rydon.co.uk>, David Peacock <DavidPeacock@jswright.co.uk>, richard moss <richardmoss@jswright.co.uk>, "d.campbell@maxfordham.com" <d.campbell@maxfordham.com>
Date: 08/05/2015 11:26
Subject: Grenfell Tower Kitchen Window Fan

Simon / Matt,

We are about to order the attached fans for the kitchens. Can you let me have any comments by this afternoon if possible before we place the order.

Please see email below also confirming suitability for fascia of 25mm and for high rise apartments.

Simon, I asked about the colour and it comes as standard in white and they don't offer the facility to get them coloured for us. However the louvre is separate (as part of the window mounting kit) so they can be sent off separately for colouring.

Kind regards,

Dave Bradbury
Design Manager
Head Office

Tel: [REDACTED] | Fax: [REDACTED] | Mob: [REDACTED] | Email: davidbradbury@jswright.co.uk | Web: www.jswright.co.uk

From: Geraint Bessant [<mailto:Geraint.Bessant@nuaire.co.uk>]
Sent: 08 May 2015 10:27
To: David Bradbury
Subject: Quote: Grenfell Tower


Hi David,

Please find attached, as discussed, the quotation required for **Grenfell Tower**.

I can confirm that the *CYFAN* unit is suitable for being mounted in the required fascia of 25mm (designed for 4mm - 32mm thickness). As there are spring loaded backdraught shutters supplied with the unit we can confirm that the unit is suitable for installation into high rise apartments as required.

I have attached the data sheets for your perusal. If you need anything further, please do not hesitate to contact me on the number below.

Kind regards,



Geraint Bessant | Residential Design Estimator

t [REDACTED] e Geraint.Bessant@nuaire.co.uk www.nuaire.co.uk
Nuaire Limited | Western Industrial Estate | Caerphilly | CF83 1NA | United Kingdom



WE MASTERED IT!

Our award winning, all-in-one Ductmaster Thermal ducting system solves the issue of insulating through un-heated spaces, helping you meet building regs and improve thermal efficiency. Lightweight material and quick-fix clip system mean no tape and sealant, so you save time and money on site.

[Find out more »www.nuaire.co.uk/residential](http://www.nuaire.co.uk/residential)



FINALIST



 @NuaireGroup

 @NuaireBuildings

 @NuaireHomes

Think before you print.

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. The email does not constitute a commitment by Nuaire Limited. Nuaire Limited is registered in England & Wales, company number 877308. Registered office: Nuaire Ltd, Western Ind Est, Caerphilly CF83 1NA.

This e-mail has been scanned for all viruses by Claranet. The service is powered by MessageLabs. For more information on a proactive anti-virus service working around the clock, around the globe, visit:
<http://www.claranet.co.uk>

[attachment "Fan Data Sheet_CYFAN-C I&M.pdf" deleted by Matt Smith/MaxFordham] [attachment "Fan Data Sheet_CYFAN-WKIT.pdf" deleted by Matt Smith/MaxFordham]

This e-mail has been scanned for all viruses by Claranet. The service is powered by MessageLabs. For more information on a proactive anti-virus service working around the clock, around the globe, visit:
<http://www.claranet.co.uk>