

**Robin Cahalarn**

---

**To:** [REDACTED]

**Cc:** John Rogers

**Subject:** Tender analysis

Ian, I have now looked through tender analysis a few minor observations :

Apex return:

1. Spec calls for Drop releases on landing doors -not euro release -Schedule 2 Page5 &11
2. Tenants will be included on colour choice -stainless steel pattern /cars & flooring.
3. Windcrest system required as boroughwide.
4. Traction sheaves to be fitted with removable rim for easy replacement.

06/08/2004

**TMO00853769/1**  
TMO00853769\_0001