

Message

---

**From:** Claire Williams [clwilliams@kctmo.org.uk]  
**Sent:** 02/10/2015 15:05:31  
**To:** Alex Bosman [abosman@kctmo.org.uk]; Alex Bosman ["/O=KC TMO/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Abosman"]  
**Subject:** RE: testing fire panel to see if it takes lifts to ground floor  
**Attachments:** image001.jpg

Hi. Just received this. Not sure if it helps us.

Our signal goes to CAS, which Rydon know ! Claire

----- Original Message -----

From: Simon Lawrence <slawrence@rydon.co.uk>  
Sent: Friday, October 2, 2015 03:43 PM  
To: Claire Williams <clwilliams@kctmo.org.uk>  
Subject: RE: testing fire panel to see if it takes lifts to ground floor  
Claire,

1. Your old existing fire alarm panel (located in the walkway lobby) has been off for about the last 3-4 months. It was switched off to isolate the fire dampers so we could replace them.
2. Our fire strategy is only based around our workforce and their safe exit. The building and it's fire strategy is the TMO's responsibility as the landlord. You dictate what happens to the residents, etc.
3. You will get a fully working AOV system with fire panel. There are no audible sounders. How the TMO manages the alarm signal should a fire occur is up to yourselves. We asked you at the very start of the project how you were going to manage the signal but have never had a response.

Regards

Simon Lawrence, ACIOB, MInstLM  
Contracts Manager

T  
M



From: Claire Williams [mailto:clwilliams@kctmo.org.uk]

Sent: 02 October 2015 14:09  
To: Simon Lawrence  
Subject: testing fire panel to see if it takes lifts to ground floor

Simon

### 1 Testing the fire alarm panel

Is it possible you can get to a smoke detector and see if by setting the alarm off that it makes the lifts go to the ground floor – or not? Can you do this today please? We are concerned that the fire panel may have some connection to the lifts that we are not aware of. Please advise if there are any problems with this, I will be on site probably after 3pm.

### 2 Your fire strategy whilst you are working at Grenfell

Can you please check that this is up to date, and send it across to me ?

### 3 Fire alarm system

I think we are just getting the AOV system in working order, but nothing else – is this right or have I missed anything?

Thanks

Claire Williams  
Project Manager

t: [REDACTED]  
m: [REDACTED]

a: The Network Hub, 292a Kensal Road, London, W10 5BE  
P Before printing, please think about the environment

---

This e-mail message has been scanned for Viruses and Content and cleared by MailMarshal

---

#### DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom

they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of Kensington & Chelsea TMO Ltd Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.