

Message

From: Siobhan Rumble [srumble@kctmo.org.uk]
Sent: 21/12/2015 15:13:31
To: Janice Wray [jwray@kctmo.org.uk]; Janice Wray ["/O=KC TMO/OU=First Administrative Group/cn=Recipients/cn=jwray"]
Subject: RE: removing self-closers
Attachments: image001.jpg

Told him

Thanks

Siobhan Rumble
Neighbourhood Manager Lancaster West

Income Manager TMO

From: Janice Wray
Sent: 17 December 2015 17:12
To: Siobhan Rumble
Subject: removing self-closers
Importance: High

Hi Siobhan

Our fire risk assessor has raised his concern that in conversation with a few of the tenants at Grenfell Tower they have advised that Seamus had disconnected the self-closers on their flat entrance door – in at least one of these cases this was said to be due to the tenant perpetually locking himself out of his flat. It is imperative that these fire doors are self-closing so I would be grateful if you could please impress this upon Seamus and insist that he refrains from disconnecting or removing any other self-closing devices.

Any queries please advise

Thanks

Janice

Janice Wray

TMO Health, Safety & Facilities Manager

t: [REDACTED]

w: www.kctmo.org.uk

a: : The Network Hub, 300 Kensal Road, W10 5BE

P Before printing, please think about the environment