

Message

From: Derrick Singleton [dsingleton@kctmorepairsdirect.co.uk]
Sent: 05/09/2016 12:42:39
To: Chelsea McRickus [cmcrickus@kctmorepairsdirect.co.uk]
CC: Renee Simmons [rsimmons@kctmorepairsdirect.co.uk]; Antonia Lee Wilmot [aleewilmot@kctmo.org.uk]; Samuel Hart [shart@kctmorepairsdirect.co.uk]
Subject: RE: FRA WORKS
Flag: Follow up

Thanks Chelsea,

Are these the jobs that Janice Wray raised following inspections by the consultant being used to check that properties comply with Fire Regulations?

Sam,
If this is ongoing work being picked up by the H&S Team would it be worth packaging it up and using Goni to do the work? As they are completing the FRA work at the moment. The only thing I'm not sure they would be able to do is the fire stopping as we may need this to be certificated.

This is a fire I've used previously for fire stopping <http://checkmatefire.com/>

Thanks
Derrick

Derrick Singleton
Operations Manager



M: [REDACTED]
T: [REDACTED]

www.kctmo.org.uk

A: Unit A, 292 Kensal Road, London, W10 5BE

Before printing, think about the environment

From: Chelsea McRickus
Sent: 05 September 2016 12:36
To: Derrick Singleton <dsingleton@kctmorepairsdirect.co.uk>
Cc: Renee Simmons <rsimmons@kctmorepairsdirect.co.uk>; Antonia Lee Wilmot <aleewilmot@kctmo.org.uk>; Samuel Hart <shart@kctmorepairsdirect.co.uk>
Subject: FRA WORKS
Importance: High

Hi Derrick,

Please see below a list of FRA works that have been raised, please advise if these are to be done in house or if they are being subbed out? If they are being subbed out please advise on who to allocate these too?

new	201623313	36 OXFORD GARDENS LONDON 70-80 TAVISTOCK ROAD	W10 5UQ	12/09/2016 10:51	15	INVALID	U	HS JOB ORDER. FIRE STOPPING TO MAINS BY ENTRANCE DOOR ...FIRE STOPPING REQUIRED AROUND MAINS CABLE BY ENTRANCE DOOR AND INTAKE CUPBOARD - ON THE 1ST FLOOR OF THE HOSTEL	KDABOH	###
new	201622945	70-80 TAVISTOCK ROAD LONDON	W11 1AN	29/09/2016 12:06	15	INVALID	NF	H/S DOOR HANDLE MISSING FROM PLADIN ROOM	KBELL	###
new	201622952	70-80 TAVISTOCK ROAD LONDON	W11 1AN	29/09/2016 12:28	60	CARPENTRY	NF	H/S LOUNGE FIRE DOOR 1 SCREW ONLY HOLDING DOOR MAGNET	KBELL	###
new	201622974	BURGESS FIELDS 57 WORNINGTON ROAD LONDON	W10 5PT	29/09/2016 13:54	15	INVALID	NF	H/S INTUMESCENT CORRIDOR DOOR NEAR FLT 11 RESTICK	KBELL	###
new	201622982	6-16 HESKETH PLACE LONDON	W11 4HN	29/09/2016 14:08	60	CARPENTRY	NF	H/S REPLACE GURDA LOCK INTAKE CUPBOARD CHUTE ROOM END OF BUI	KBELL	###
new	201622988	GRENFELL TOWER LANCASTER WEST ESTATE LONDON	W11 1TQ	29/09/2016 14:23	217	CARPENTRY	NF	FRA WORKS NEW FD30 DOOR TO BASEMENT BOILER R	KBELL	###
new	201622993	BURGESS FIELDS 57 WORNINGTON ROAD LONDON	W10 5PT	29/09/2016 14:31	15	INVALID	NF	FRA WORKS FIRE STOPPING TO PLASTERWALLS A BOEMAN FOR LOCATIO	KBELL	###
new	201622995	GRENFELL TOWER LANCASTER WEST ESTATE LONDON	W11 1TQ	29/09/2016 14:35	217	CARPENTRY	NF	FRA WORKS REPAIR OR REPLACE 16TH FLOOR COMMUNAL DOOR	KBELL	###
new	201623006	FLAT 24 GRENFELL TOWER LANCASTER WEST ESTATE LONDON	W11 1TG	29/09/2016 14:46	812	CARPENTRY	N	FRA WORKS NEW FRONT DOOR RERQUIRED	KBELL	###
new	201623020	BERENGER TOWER 1-51 WORLDS END	SW10 0EF	29/09/2016 15:02	60	CARPENTRY	NF	FRA WORKS NEW DOOR CLOSER 15TH FLOOR STAIRCASE LIFT LOBBY	KBELL	###



TMO00860824/4
TMO00000000_0000