

Robin Cahalarn

From: Roger Green
Sent: 24 March 2006 09:27
To: Robin Cahalarn
Cc: 'Steve ellis (steve@bylcl.co.uk)'; 'Richard braxton (richard.braxton@apex-lifts.co.uk)'
Subject: RE: Grenfell Tower lift motor room

Robin

Their supervisor has told me they are going to be back their today and next week to complete and tidy up .
Will also need to meet with lift engineers to test and prove the FA system brings the lifts back to the ground floor when it goes into alarm .

Date TBA

regards Roger Green
Electrical Engineer
Kensington & Chelsea TMO
tel [REDACTED]
mob [REDACTED]

From: Robin Cahalarn
Sent: 23 March 2006 13:20
To: Roger Green
Cc: Steve ellis (steve@bylcl.co.uk); Richard braxton (richard.braxton@apex-lifts.co.uk)
Subject: Grenfell Tower lift motor room

Just to confirm our conversation regarding brick dust etc left behind by operatives installing alarm recall system ,can you please arrange for them to return and clean up to leave as found at an early opportunity .

Robin Cahalarn
Senior Lift Engineer

[REDACTED]

24/03/2006

TMO00863273/1

TMO00863273_0001