

Robin Cahalarn

To: Roger Green; Janice Jones
Cc: Janice Wray
Subject: RE: Grenfell tower connecting up fire recall

brill

From: Roger Green
Sent: 11 April 2006 13:27
To: Robin Cahalarn; Janice Jones
Cc: Janice Wray
Subject: RE: Grenfell tower connecting up fire recall



Robin

We tested the new fire alarm , in the lift motor room , and the operation of bringing both lifts down to ground floor (in the event of a fire alarm) , it all worked as required .
The site has been cleared up as requested

Janice Jones

Could you advise tenants in the tower that the lifts, in the event of a fire alarm , will automatically go down to the ground floor and doors will open to allow passengers out .Once the car is empty the doors will shut and the lift operation will cease until the fire alarm is reset .

regards Roger

From: Robin Cahalarn
Sent: 10 April 2006 09:17
To: Roger Green
Cc: 'Gary Poynter'
Subject: Grenfell tower connecting up fire recall

Gary Poynter (apex [REDACTED] rang he will have tester on site tommorrow tuesday 11.4.06 at 9.00am to meet fire alarm engineer please confirm

Robin Cahalarn
Senior Lift Engineer

[REDACTED]

12/04/2006