Message

From:	Alex Fomin [Alex.Fomin@lhc.gov.uk]
Sent:	27/06/2011 08:15:07
То:	Abigail Acosta [aacosta@kctmo.org.uk]
Subject:	RE: King Charles House

Abi, good morning

It was never intended to inspect all properties in the contract. I have inspected only those properties which had doors installed or being installed on that day, obviously this one was installed at the later time. If you require me to visit that particular door please advise.

Kind regards

Alex Fomin Technical Officer South East & South West of England



www.lhc.gov.uk

LHC

Royal House, 4th Floor, 2-4 Vine Street, Uxbridge, UB8 1QE

This e-mail may contain confidential information and/or copyright material and is intended for the use of the addressee only. Unauthorised use may be unlawful. If you receive this email by mistake, please advise the sender immediately by using the e-mail reply facility. Please note that any reply you make to this e-mail may be seen by other persons other than the main recipient.

From: Abigail Acosta [mailto:aacosta@kctmo.org.uk] Sent: 27 June 2011 09:08 To: Alex Fomin Subject: FW: King Charles House

Alex Good Morning

Hope you're keeping well

See further comment below with regards to report.

Flat 39 was inspected by Carl as works in progress but not on your report.

Could you ensure that the report is reflective of actual works being undertaken for audit purposes.

Thanks

Abigail Acosta Project Manager of Assets, Investment & Engineering B



. aacosta@kctmo.org.uk (www.kctmo.org.uk)

Image: The Network Hub, Units 102-108, 292A Kensal Road, London W10 5BE

Before printing, please think about the environment

From:

[mailto: Sent: 24 June 2011 19:06 To: Abigail Acosta Subject: Re: King Charles House

Hi Abigail

I looked for flat 39 on the reports you have been sent by LHS ? I could not see flat 39 mentioned as being inspected?

Carl

-----Original Message-----From: Abigail Acosta <aacosta@kctmo.org.uk> To: 'Natasha Brown' <natasha.brown@masterdor.co.uk>; CC: 'Andy Webster' <andy.webster@masterdor.co.uk> Sent: Fri, 24 Jun 2011 15:10 Subject: RE: King Charles House

Many thanks

Abigail Acosta Project Manager of Assets, Investment & Engineering B



. aacosta@kctmo.org.uk (www.kctmo.org.uk)

⊠: The Network Hub, Units 102-108 , 292A Kensal Road, London W10 5BE

Before printing, please think about the environment

From: Natasha Brown [mailto:natasha.brown@masterdor.co.uk] Sent: 24 June 2011 15:08 To: Abigail Acosta; Cc: 'Andy Webster' Subject: RE: King Charles House

Hi Abi

I have spoken with resident at 13 King Charles and at present he is able to open/close and lock his door. I will pop over to him on Monday and arrange for a fitter to fix the closing device.

39 King Charles I will make some enquiries with fitter and get back to you asap

Regards

Natasha

From: Abigail Acosta [mailto:aacosta@kctmo.org.uk] Sent: 24 June 2011 14:52

To: ' Cc: 'Natasha Brown' Subject: RE: King Charles House

Carl hi

I have passed on to Masterdor for them to action

Thanks

Abigail Acosta Project Manager of Assets, Investment & Engineering



1: aacosta@kctmo.org.uk () www.kctmo.org.uk

⊠: The Network Hub, Units 102-108 , 292A Kensal Road, London W10 5BE

Before printing, please think about the environment

From: [mailto: Sent: 24 June 2011 12:32 To: Abigail Acosta Subject: King Charles House

Abi

Good morning, I visited King Charles House yesterday and two residents showed me their new flat entrance doors.

Flat 39 to fit the door some plaster etc had to be removed internally in the flat entrance lobby area the walls have not been made good.

Flat 13 the self closing device has come out of the door, the occupant contacted TMO and explained this and it was a newly fitted door etc and the TMO call person stated that Morrisons who come out and fix it

Carl

This e-mail message has been scanned for Viruses and Content and cleared by MailMarshal

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential

information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute

or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent

those of Kensington & Chelsea TMO Ltd Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.

++++ Message Scanning REF:294-avs2-1308923542 ++++

This e-mail message has been scanned for Viruses and Content and cleared by MailMarshal

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential

information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute

or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent

those of Kensington & Chelsea TMO Ltd Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.

This e-mail message has been scanned for Viruses and Content and cleared by MailMarshal

DISCLAIMER:

This E-mail and any files transmitted with are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the System Administrator. This message may contain confidential

information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute

or copy this email.

Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent

those of Kensington & Chelsea TMO Ltd Finally, the recipient should check this email and any attachments for the presence of viruses. Kensington & Chelsea TMO Ltd accepts no liability for any damage caused by any Virus transmitted by this email.