
From: Claire Williams
Sent: 12 December 2016 17:27
To: [REDACTED] jwray@kctmo.org.uk
Subject: FW: 112 grenfell tower-new front door
Attachments: 20161212_125522.jpg; 20161212_125526.jpg; image001.jpg

Dear Mr Azab

I hope you are well.

We spoke a while ago about your new flat front door at Grenfell – how it needed to be a fire door.

I was at Grenfell today and saw your tenants who let me see how it looked.

Can you please confirm it is an FD 30 (capable of holding back fire for 30 mins), as I could see that it had no self closing device on it, which means it does not meet the regulations.

I have copied in my health and safety colleague Janice Wray, who will be taking this forward.

Thanks

Claire Williams

Project Manager

<http://www.kctmo.org.uk>

t: [REDACTED]
m: [REDACTED]

a: The Network Hub, 292a Kensal Road, London, W10 5BE P Before printing, please think about the environment

From: Claire Williams
Sent: 12 December 2016 16:23
To: Claire Williams <cwilliams@kctmo.org.uk>
Subject: 112 grenfell tower-new front door