

---

**From:** John Tatham <jtatham@kctmorepairsdirect.co.uk>  
**Sent:** 19 March 2015 17:43  
**To:** Janice Wray  
**Subject:** RE: Communal fire doors

Received and understood.

---

**From:** Janice Wray  
**Sent:** 19 March 2015 17:09  
**To:** John Tatham  
**Subject:** Communal fire doors

Hi John

I have just spoken to our Fire Risk Assessor and he has advised that we should stop the contractors routing any more doors and fitting seals. The doors are compliant currently but routing may result in fire retardance being lost, intumescent being damaged etc. Also where this is done there is a requirement to confirm refurbished doors meet all requirements of current Regns - would need testing to do this. Grateful if you could stop contractors doing any more of this

Thanks

Janice

Sent from Samsung Mobile